

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: CURRY

Conventional or Direct Filtration

Month/Year: Mar-25

System Name:	Rainbow Rock Service Association			ID#: 41	01361	WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	POL	POL	POL	POL	POL	POL	
2	POL	POL	POL	POL	POL	POL	
3	POL	POL	POL	POL	POL	POL	
4	POL	POL	POL	POL	POL	POL	
5	POL	POL	POL	POL	0.06	0.05	0.06
6	0.05	0.05	POL	POL	POL	POL	0.05
7	POL	POL	POL	POL	POL	POL	
8	POL	POL	POL	POL	POL	POL	
9	POL	POL	POL	POL	POL	POL	
10	POL	POL	POL	POL	POL	POL	
11	POL	POL	0.20	0.04	POL	POL	0.20
12	POL	POL	POL	POL	POL	POL	
13	POL	POL	POL	POL	POL	POL	
14	POL	POL	0.05	0.05	POL	POL	0.05
15	POL	POL	POL	POL	POL	POL	
16	POL	POL	POL	POL	POL	POL	
17	POL	POL	POL	POL	POL	POL	
18	POL	POL	POL	POL	POL	POL	
19	POL	POL	0.20	0.15	0.05	POL	0.20
20	POL	POL	POL	POL	POL	POL	
21	POL	POL	POL	POL	POL	POL	
22	POL	POL	POL	POL	POL	POL	
23	POL	POL	POL	POL	POL	POL	
24	POL	POL	POL	POL	POL	POL	
25	POL	POL	0.07	0.05	0.05	0.05	0.07
26	0.05	0.05	POL	POL	POL	POL	0.05
27	POL	POL	POL	POL	POL	POL	
28	POL	POL	POL	POL	POL	POL	
29	POL	POL	POL	POL	POL	POL	
30	POL	POL	POL	POL	POL	POL	
31	POL	POL	POL	POL	POL	POL	

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?

Yes / No

All 4-hour turbidity readings $\leq$ 1 NTU?

Yes / No

All turbidity readings < IFE² triggers

Yes / No

CT's met everyday?
(see back)

Yes / No

All Cl₂ residual at entry point
 $\geq$ 0.2 mg/l?

Yes / No

Notes:

POL & Blanks = plant off line

PRINTED NAME: Jonathan Woody

SIGNATURE: *Jonathan Woody*

DATE: 4-9-25

PHONE #: (541) 643-6137

CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

A

System Name: Rainbow Rock Service Association

ID#: 41

01361

Month/Year:

Mar-25

Disinfection *Giardia*
Log Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1		71						20
2		71						20
3		71						20
4		71						20
5	0.69	71	49.0	11.9	7.40	37.8	YES	20
6	1.22	71	86.6	10.0	7.40	45.5	YES	20
7		71						20
8		71						20
9		71						20
10		71						20
11	1.38	71	98.0	11.0	7.45	44.1	YES	20
12		71						20
13		71						20
14	1.07	71	76.0	10.0	7.40	44.7	YES	20
15		71						20
16		71						20
17		71						20
18		71						20
19	1.27	71	90.2	10.1	7.45	46.3	YES	20
20		71						20
21		71						20
22		71						20
23		71						20
24		71						20
25	1.32	71	93.7	13.0	7.40	37.4	YES	20
26	1.16	71	82.4	12.4	7.37	38.2	YES	20
27		71						20
28		71						20
29		71						20
30		71						20
31		71						20

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013

Oregon DHS - Drinking Water Services – Surface Water Quality DataSystem Name: Rainbow Rock Service Association

ID# 41 01361

Month/Year: Mar / 2025Minimum UVT [%] during month: 88Duty sensor variation from reference sensor %: 0%Minimum Validated UVT : 75%

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced (Mo. Sum {B}) , (Mo. Sum {A}) * 100 [%]
	[gpm/unit]	[mW/cm2]	[Y or N]	[gal]	[gal]	
1	POL	POL	POL	POL	0	
2	POL	POL	POL	POL	0	
3	POL	POL	POL	POL	0	
4	POL	POL	POL	POL	0	
5	26	54.2	Y	9,512	0	
6	26	54	Y	7,134	0	
7	POL	POL	POL	POL	0	
8	POL	POL	POL	POL	0	
9	POL	POL	POL	POL	0	
10	POL	POL	POL	POL	0	
11	26	55	Y	10,268	0	
12	POL	POL	POL	POL	0	
13	POL	POL	POL	POL	0	
14	26	53.3	Y	10,009	0	
15	POL	POL	POL	POL	0	
16	POL	POL	POL	POL	0	
17	POL	POL	POL	POL	0	
18	POL	POL	POL	POL	0	
19	26	54.9	Y	10,252	0	
20	POL	POL	POL	POL	0	
21	POL	POL	POL	POL	0	
22	POL	POL	POL	POL	0	
23	POL	POL	POL	POL	0	
24	POL	POL	POL	POL	0	
25	26	55.1	Y	18,252	0	
26	26	55.1	Y	6,084	0	
27	POL	POL	POL	POL	0	
28	POL	POL	POL	POL	0	
29	POL	POL	POL	POL	0	
30	POL	POL	POL	POL	0	
31	POL	POL	POL	POL	0	
Monthly Cumulative % Off-Spec Water Produced						0

rev 1/11 I:\MC\forms\Turbidity Report Form – UV and opt m POL= Plant offline

Signature: Op Cert #: 7232Date: 4-9-25