

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: CURRY

Conventional or Direct Filtration

Month/Year: Apr-25

System Name:	Rainbow Rock Service Association			ID#: 41	01361	WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	POL	POL	POL	POL	POL	POL	
2	0.05	0.05	0.05	0.04	0.04	POL	0.05
3	POL	POL	POL	POL	POL	POL	
4	POL	POL	POL	POL	POL	POL	
5	POL	POL	POL	POL	POL	POL	
6	POL	POL	POL	POL	POL	POL	
7	POL	POL	POL	POL	POL	POL	
8	POL	POL	POL	POL	0.06	0.05	0.06
9	0.05	0.05	0.05	0.05	0.06	POL	0.06
10	POL	POL	POL	POL	POL	POL	
11	POL	POL	POL	POL	POL	POL	
12	POL	POL	POL	POL	POL	POL	
13	POL	POL	POL	POL	POL	POL	
14	POL	POL	POL	POL	POL	POL	
15	POL	POL	POL	0.04	0.04	POL	0.04
16	POL	POL	POL	POL	POL	POL	
17	POL	POL	POL	POL	POL	POL	
18	POL	POL	POL	POL	POL	POL	
19	POL	POL	POL	POL	POL	POL	
20	POL	POL	POL	POL	POL	POL	
21	POL	POL	POL	POL	POL	POL	
22	POL	POL	0.05	0.05	0.05	0.05	0.05
23	0.05	0.05	POL	POL	POL	POL	0.05
24	POL	POL	POL	POL	POL	POL	
25	POL	POL	POL	POL	POL	POL	
26	POL	POL	POL	POL	POL	POL	
27	POL	POL	POL	POL	POL	POL	
28	POL	POL	POL	POL	POL	POL	
29	POL	POL	POL	POL	0.05	0.05	0.05
30	0.05	0.05	0.05	0.05	POL	POL	0.05
31	POL	POL	POL	POL	POL	POL	

Conventional or Direct Filtration

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?

Yes / No

All 4-hour turbidity readings $\leq$ 1 NTU?

Yes / No

All turbidity readings < IFE² triggers

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes / No

All Cl₂ residual at entry point
 $\geq$ 0.2 mg/l?

Yes / No

Notes:

PRINTED NAME: Jonathan Woody

SIGNATURE: *Jonathan Woody*

DATE: 5-8-25

PHONE #: (541) 643-6137

CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Rainbow Rock Service Association ID#: 41 01361 Month/Year: Apr-25					WTP - : A	
					Disinfection <i>Giardia</i> Log Inactiv:	1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1	0.79	71	56.1	11.6	7.36	38.5	YES	20
2	1.54	71	109.3	11.8	7.40	41.9	YES	20
3	POL	71	POL	POL	POL	POL	POL	20
4	POL	71	POL	POL	POL	POL	POL	20
5	POL	71	POL	POL	POL	POL	POL	20
6	POL	71	POL	POL	POL	POL	POL	20
7	POL	71	POL	POL	POL	POL	POL	20
8	0.93	71	66.0	11.9	7.38	38.6	YES	20
9	1.38	71	98.0	12.8	7.30	36.8	YES	20
10	POL	71	POL	POL	POL	POL	POL	20
11	POL	71	POL	POL	POL	POL	POL	20
12	POL	71	POL	POL	POL	POL	POL	20
13	POL	71	POL	POL	POL	POL	POL	20
14	POL	71	POL	POL	POL	POL	POL	20
15	1.22	71	86.6	12.5	7.36	37.7	YES	20
16	POL	71	POL	POL	POL	POL	POL	20
17	POL	71	POL	POL	POL	POL	POL	20
18	POL	71	POL	POL	POL	POL	POL	20
19	POL	71	POL	POL	POL	POL	POL	20
20	POL	71	POL	POL	POL	POL	POL	20
21	POL	71	POL	POL	POL	POL	POL	20
22	1.29	71	91.6	12.9	7.30	36.2	YES	20
23	1.24	71	88.0	11.5	7.30	39.9	YES	20
24	POL	71	POL	POL	POL	POL	POL	20
25	POL	71	POL	POL	POL	POL	POL	20
26	POL	71	POL	POL	POL	POL	POL	20
27	POL	71	POL	POL	POL	POL	POL	20
28	POL	71	POL	POL	POL	POL	POL	20
29	0.84	71	59.6	14.4	7.32	31.3	YES	20
30	1.15	71	81.7	13.3	7.36	35.5	YES	20
31		71						20

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.


Revised October 2013

Oregon DHS - Drinking Water Services – Surface Water Quality DataSystem Name: **Rainbow Rock Service Association**

ID# 41 01361

Month/Year: **Apr / 2025**Minimum UVT [%] during month: 88Duty sensor variation from reference sensor %: 0%Minimum Validated UVT : 75%

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm/unit]	[^{mW} /cm ²]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	26	55	Y	4,760	0	
2	26	54.9	Y	20,230	0	
3	POL	POL	POL	POL	0	
4	POL	POL	POL	POL	0	
5	POL	POL	POL	POL	0	
6	POL	POL	POL	POL	0	
7	POL	POL	POL	POL	0	
8	26	55.1	Y	9,520	0	
9	26	53.9	Y	19,040	0	
10	POL	POL	POL	POL	0	
11	POL	POL	POL	POL	0	
12	POL	POL	POL	POL	0	
13	POL	POL	POL	POL	0	
14	POL	POL	POL	POL	0	
15	26	55.1	Y	12,381	0	
16	POL	POL	POL	POL	0	
17	POL	POL	POL	POL	0	
18	POL	POL	POL	POL	0	
19	POL	POL	POL	POL	0	
20	POL	POL	POL	POL	0	
21	POL	POL	POL	POL	0	
22	26	55.1	Y	18,649	0	
23	26	54	Y	7,679	0	
24	POL	POL	POL	POL	0	
25	POL	POL	POL	POL	0	
26	POL	POL	POL	POL	0	
27	POL	POL	POL	POL	0	
28	POL	POL	POL	POL	0	
29	26	56.3	Y	9,040	0	
30	26	55.2	Y	13,560	0	
31					0	
Monthly Cumulative % Off-Spec Water Produced						0

Signature: Op Cert #: 7232Date: 5-8-25