

OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **CURRY**
 Month/Year: **May-25**

System Name:	Rainbow Rock Service Association			ID#: 41	01361	WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	POL	POL	POL	0.07	POL	POL	0.07
2	POL	POL	POL	POL	POL	POL	
3	POL	POL	POL	POL	POL	POL	
4	POL	POL	POL	POL	POL	POL	
5	POL	POL	POL	POL	POL	POL	
6	POL	POL	POL	POL	POL	POL	
7	POL	POL	POL	POL	0.05	0.05	0.05
8	0.05	0.05	0.05	0.05	0.05	POL	0.05
9	POL	POL	POL	POL	POL	POL	
10	POL	POL	POL	POL	POL	POL	
11	POL	POL	POL	POL	POL	POL	
12	POL	POL	POL	POL	POL	POL	
13	POL	POL	POL	POL	POL	POL	
14	POL	POL	POL	POL	POL	POL	
15	POL	POL	POL	POL	0.05	0.04	0.04
16	0.04	0.04	POL	POL	POL	POL	0.04
17	POL	POL	POL	POL	POL	POL	
18	POL	POL	POL	POL	POL	POL	
19	POL	POL	POL	POL	POL	POL	
20	POL	POL	POL	POL	POL	POL	
21	POL	POL	0.05	0.04	0.04	0.04	0.05
22	0.04	0.04	POL	POL	POL	POL	0.04
23	POL	POL	POL	POL	POL	POL	
24	POL	POL	POL	POL	POL	POL	
25	POL	POL	POL	POL	POL	POL	
26	POL	POL	POL	POL	POL	POL	
27	POL	POL	POL	POL	POL	POL	
28	POL	POL	0.04	0.04	0.04	0.04	0.04
29	0.04	0.04	POL	POL	POL	POL	0.04
30	POL	POL	POL	POL	POL	POL	
31	POL	POL	POL	POL	POL	POL	

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	<u>Yes</u> / No	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	<u>Yes</u> / No	<u>Yes</u> / No	<u>Yes</u> / No
All turbidity readings < IFE ² triggers	<u>Yes</u> / No		
Notes:		PRINTED NAME: Jonathan Woody SIGNATURE: <u>[Signature]</u> DATE: <u>6-9-25</u> PHONE #: (541) 643-6137 CERT #: 7232	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

A

System Name:	Rainbow Rock Service Association	ID#: 41	01361	Month/Year:	May-25	Disinfection <i>Giardia</i> Log Inactiv:	1
--------------	----------------------------------	---------	-------	-------------	--------	---	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.69	71	49.0	12.5	7.33	35.1	YES	20
2	POL	71	POL	POL	POL	POL	POL	20
3	POL	71	POL	POL	POL	POL	POL	20
4	POL	71	POL	POL	POL	POL	POL	20
5	POL	71	POL	POL	POL	POL	POL	20
6	POL	71	POL	POL	POL	POL	POL	20
7	0.63	71	44.7	14.6	7.30	30.0	YES	20
8	0.65	71	46.2	13.8	7.30	31.7	YES	20
9	POL	71	POL	POL	POL	POL	POL	20
10	POL	71	POL	POL	POL	POL	POL	20
11	POL	71	POL	POL	POL	POL	POL	20
12	POL	71	POL	POL	POL	POL	POL	20
13	POL	71	POL	POL	POL	POL	POL	20
14	POL	71	POL	POL	POL	POL	POL	20
15	0.88	71	62.5	13.0	7.30	34.3	YES	20
16	1.18	71	83.8	11.8	7.26	38.3	YES	20
17	POL	71	POL	POL	POL	POL	POL	20
18	POL	71	POL	POL	POL	POL	POL	20
19	POL	71	POL	POL	POL	POL	POL	20
20	POL	71	POL	POL	POL	POL	POL	20
21	1.34	71	95.1	13.8	7.30	34.3	YES	20
22	1.2	71	85.2	12.6	7.26	36.0	YES	20
23	POL	71	POL	POL	POL	POL	POL	20
24	POL	71	POL	POL	POL	POL	POL	20
25	POL	71	POL	POL	POL	POL	POL	20
26	POL	71	POL	POL	POL	POL	POL	20
27	POL	71	POL	POL	POL	POL	POL	20
28	0.96	71	68.2	14.0	7.20	31.2	YES	20
29	0.91	71	64.6	13.1	7.24	33.5	YES	20
30	POL	71	POL	POL	POL	POL	POL	20
31	POL	71	POL	POL	POL	POL	POL	20

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013

Oregon DHS - Drinking Water Services – Surface Water Quality Data

System Name: **Rainbow Rock Service**
Association

ID# 41 01361

Month/Year: May / 2025

Minimum UVT [%] during month: 88Duty sensor variation from reference sensor %: 0%Minimum Validated UVT: 75%

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm/unit]	[^{mW} /cm ²]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	26	55.1	Y	2,268	0	
2	POL	POL	POL	POL	0	
3	POL	POL	POL	POL	0	
4	POL	POL	PP	POL	0	
5	POL	POL	POL	POL	0	
6	POL	POL	POL	POL	0	
7	26	56	Y	8,104	0	
8	26	55.2	Y	17,221	0	
9	POL	POL	POL	POL	0	
10	POL	POL	POL	POL	0	
11	POL	POL	POL	POL	0	
12	POL	POL	POL	POL	0	
13	POL	POL	POL	POL	0	
14	POL	POL	POL	POL	0	
15	26	54.8	Y	11,535	0	
16	26	56	Y	8,967	0	
17	POL	POL	POL	POL	0	
18	POL	POL	POL	POL	0	
19	POL	POL	POL	POL	0	
20	POL	POL	POL	POL	0	
21	26	55.8	Y	18,738	0	
22	26	54.8	Y	5,205	0	
23	POL	POL	POL	POL	0	
24	POL	POL	POL	POL	0	
25	POL	POL	POL	POL	0	
26	POL	POL	POL	POL	0	
27	POL	POL	POL	POL	0	
28	26	56	Y	18,540	0	
29	26	56.8	Y	6,180	0	
30	POL	POL	POL	POL	0	
31	POL	POL	POL	POL	0	
Monthly Cumulative % Off-Spec Water Produced						0

Signature: Op Cert #: 7232Date: 6-9-25