

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: CURRY

Conventional or Direct Filtration

Month/Year: Jun-25

System Name: Rainbow Rock Service Association		ID#: 41 01361		WTP : TP - A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	POL	POL	POL	POL	POL	POL	
2	POL	POL	POL	POL	POL	POL	
3	POL	POL	POL	POL	POL	POL	
4	POL	POL	0.05	0.04	0.04	0.04	0.05
5	0.04	0.04	POL	POL	POL	POL	0.04
6	POL	POL	POL	POL	POL	POL	
7	POL	POL	POL	POL	POL	POL	
8	POL	POL	POL	POL	POL	POL	
9	POL	POL	POL	POL	POL	POL	
10	POL	POL	POL	POL	POL	POL	
11	POL	POL	0.05	0.04	0.04	0.04	0.05
12	0.04	0.04	POL	POL	POL	POL	0.04
13	POL	POL	POL	POL	POL	POL	
14	POL	POL	POL	POL	POL	POL	
15	POL	POL	POL	POL	POL	POL	
16	POL	POL	POL	POL	POL	POL	
17	POL	POL	0.04	0.04	0.04	0.04	0.04
18	0.04	0.04	POL	POL	POL	POL	0.04
19	POL	POL	POL	POL	POL	POL	
20	POL	POL	POL	POL	POL	POL	
21	POL	POL	POL	POL	POL	POL	
22	POL	POL	POL	POL	POL	POL	
23	POL	POL	POL	POL	POL	POL	
24	POL	POL	0.04	0.04	0.04	0.04	0.04
25	0.04	0.04	POL	POL	POL	POL	0.04
26	POL	POL	POL	POL	POL	POL	
27	POL	POL	POL	POL	POL	POL	
28	POL	POL	POL	POL	POL	POL	
29	POL	POL	POL	POL	POL	POL	
30	POL	POL	0.07	0.06	0.05	0.05	0.07
31	POL	POL	POL	POL	POL	POL	

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings \leq 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl ₂ residual at entry point \geq 0.2 mg/l?
All 4-hour turbidity readings \leq 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		

Notes:	PRINTED NAME: Jonathan Woody	
	SIGNATURE: <i>Jonathan Woody</i>	DATE: 7-6-25
	PHONE #: (541) 643-6137	CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

A

System Name: Rainbow Rock Service Association

ID#: 41

01361

Month/Year:

Jun-25

Disinfection *Giardia*
Log Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	POL	71	POL	POL	POL	POL		20
2	POL	71	POL	POL	POL	POL		20
3	POL	71	POL	POL	POL	POL		20
4	2.08	71	147.7	15.9	7.20	31.2	YES	20
5	1.58	71	112.2	14.6	7.26	32.9	YES	20
6	POL	71	POL	POL	POL	POL		20
7	POL	71	POL	POL	POL	POL		20
8	POL	71	POL	POL	POL	POL		20
9	POL	71	POL	POL	POL	POL		20
10	POL	71	POL	POL	POL	POL		20
11	1.64	71	116.4	14.5	7.27	33.5	YES	20
12	1.62	71	115.0	13.8	7.23	34.5	YES	20
13	POL	71	POL	POL	POL	POL		20
14	POL	71	POL	POL	POL	POL		20
15	POL	71	POL	POL	POL	POL		20
16	POL	71	POL	POL	POL	POL		20
17	1.46	71	103.7	14.6	7.23	32.1	YES	20
18	1.56	71	110.8	13.9	7.20	33.7	YES	20
19	POL	71	POL	POL	POL	POL		20
20	POL	71	POL	POL	POL	POL		20
21	POL	71	POL	POL	POL	POL		20
22	POL	71	POL	POL	POL	POL		20
23	POL	71	POL	POL	POL	POL		20
24	1.32	71	93.7	14.8	7.24	31.3	YES	20
25	1.36	71	96.6	14.2	7.20	32.2	YES	20
26	POL	71	POL	POL	POL	POL		20
27	POL	71	POL	POL	POL	POL		20
28	POL	71	POL	POL	POL	POL		20
29	POL	71	POL	POL	POL	POL		20
30	1.44	71	102.2	16.0	7.30	29.9	YES	20
31		71						20

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013

Oregon DHS - Drinking Water Services – Surface Water Quality DataSystem Name: **Rainbow Rock Service Association**

ID# 41 01361

Month/Year: Jun / 2025

Minimum UVT [%] during month: 88Duty sensor variation from reference sensor %: 0%Minimum Validated UVT : 75%

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm/unit]	[^{mW} /cm ²]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	POL	POL	POL	POL	0	
2	POL	POL	POL	POL	0	
3	POL	POL	POL	POL	0	
4	26	56	Y	17,172	0	
5	26	55.2	Y	5,724	0	
6	POL	POL	POL	POL	0	
7	POL	POL	POL	POL	0	
8	POL	POL	POL	POL	0	
9	POL	POL	POL	POL	0	
10	POL	POL	POL	POL	0	
11	26	55.8	Y	19,963	0	
12	26	55.1	Y	6,654	0	
13	POL	POL	POL	POL	0	
14	POL	POL	POL	POL	0	
15	POL	POL	POL	POL	0	
16	POL	POL	POL	POL	0	
17	26	55.6	Y	19,260	0	
18	26	56	Y	6,420	0	
19	POL	POL	POL	POL	0	
20	POL	POL	POL	POL	0	
21	POL	POL	POL	POL	0	
22	POL	POL	POL	POL	0	
23	POL	POL	POL	POL	0	
24	26	56	Y	18,720	0	
25	26	55.5	Y	6,240	0	
26	POL	POL	POL	POL	0	
27	POL	POL	POL	POL	0	
28	POL	POL	POL	POL	0	
29	POL	POL	POL	POL	0	
30	26	56	Y	15,164	0	
31					0	
Monthly Cumulative % Off-Spec Water Produced						0

Signature: Op Cert #: 7232Date: 7-6-25