

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: CURRY

Conventional or Direct Filtration

Month/Year: Jul-25

System Name: Rainbow Rock Service Association		ID#: 41		01361		WTP: TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.05	0.05	0.05	0.05	POL	POL	0.05
2	POL	POL	POL	POL	POL	POL	
3	POL	POL	POL	POL	POL	POL	
4	POL	POL	POL	POL	POL	POL	
5	POL	POL	POL	POL	POL	POL	
6	POL	POL	POL	POL	POL	POL	
7	POL	POL	POL	POL	0.07	0.06	0.07
8	0.05	0.05	0.05	0.05	POL	POL	0.05
9	POL	POL	0.06	0.05	0.05	0.05	0.06
10	0.05	0.05	POL	POL	POL	POL	0.05
11	POL	POL	POL	POL	POL	POL	
12	POL	POL	POL	POL	POL	POL	
13	POL	POL	POL	POL	POL	POL	
14	POL	POL	POL	POL	POL	POL	
15	POL	POL	0.08	0.06	0.06	0.06	0.08
16	0.05	0.05	POL	POL	POL	POL	0.05
17	POL	POL	0.07	0.07	POL	POL	0.07
18	POL	POL	POL	POL	POL	POL	
19	POL	POL	POL	POL	POL	POL	
20	POL	POL	POL	POL	POL	POL	
21	POL	POL	POL	POL	POL	POL	
22	POL	POL	0.08	0.06	0.06	0.06	0.08
23	0.05	0.05	0.05	0.05	POL	POL	0.05
24	POL	POL	POL	POL	POL	POL	
25	POL	POL	0.07	POL	POL	POL	0.07
26	POL	POL	POL	POL	POL	POL	
27	POL	POL	POL	POL	POL	POL	
28	POL	POL	POL	0.07	0.06	0.06	0.07
29	0.07	0.07	0.05	0.07	0.07	POL	0.07
30	POL	POL	POL	POL	POL	POL	
31	POL	POL	0.09	0.07	0.07	0.06	0.09

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		

Notes:	PRINTED NAME: Jonathan Woody	
	SIGNATURE: <i>Jonathan Woody</i>	DATE: 8-8-25
	PHONE #: (541) 643-6137	CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form
WTP - :
A
System Name: Rainbow Rock Service Association

ID#: 41

01361
Month/Year:
Jul-25
**Disinfection *Giardia*
Log Inactiv:**
1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.43	71	101.5	16.0	7.28	29.7	YES	20
2	POL	71	POL	POL	POL	POL	POL	20
3	POL	71	POL	POL	POL	POL	POL	20
4	POL	71	POL	POL	POL	POL	POL	20
5	POL	71	POL	POL	POL	POL	POL	20
6	POL	71	POL	POL	POL	POL	POL	20
7	1.1	71	78.1	16.0	7.20	27.8	YES	20
8	1.23	71	87.3	15.3	7.17	29.2	YES	20
9	0.83	71	58.9	15.4	7.11	27.1	YES	20
10	2.15	71	152.7	15.0	7.10	32.2	YES	20
11	POL	71	POL	POL	POL	POL	POL	20
12	POL	71	POL	POL	POL	POL	POL	20
13	POL	71	POL	POL	POL	POL	POL	20
14	POL	71	POL	POL	POL	POL	POL	20
15	1.75	71	124.3	16.4	7.35	30.8	YES	20
16	1.12	71	79.5	14.9	7.50	33.5	YES	20
17	1.06	71	75.3	14.2	7.36	33.1	YES	20
18	POL	71	POL	POL	POL	POL	POL	20
19	POL	71	POL	POL	POL	POL	POL	20
20	POL	71	POL	POL	POL	POL	POL	20
21	POL	71	POL	POL	POL	POL	POL	20
22	1.89	71	134.2	16.2	7.10	28.9	YES	20
23	1.43	71	101.5	15.5	7.20	29.8	YES	20
24	POL	71	POL	POL	POL	POL	POL	20
25	1.66	71	117.9	16.0	7.10	28.5	YES	20
26	POL	71	POL	POL	POL	POL	POL	20
27	POL	71	POL	POL	POL	POL	POL	20
28	1.86	71	132.1	16.5	7.05	27.7	YES	20
29	1.84	71	130.6	15.4	7.04	29.6	YES	20
30	POL	71	POL	POL	POL	POL	POL	20
31	1.65	71	117.2	16.8	7.10	27.0	YES	20

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013


Oregon DHS - Drinking Water Services – Surface Water Quality DataSystem Name: **Rainbow Rock Service Association**

ID# 41 01361

Month/Year: Jul / 2025

Minimum UVT [%] during month: 88Duty sensor variation from reference sensor %: 0%Minimum Validated UVT : 75%

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm/unit]	[^{mW} /cm ²]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	26	55.2	Y	15,164	0	
2	POL	POL	POL	POL	0	
3	POL	POL	POL	POL	0	
4	POL	POL	POL	POL	0	
5	POL	POL	POL	POL	0	
6	POL	POL	POL	POL	0	
7	26	54.9	Y	8,780	0	
8	26	56	Y	14,978	0	
9	26	54.6	Y	18,414	0	
10	26	56	Y	6,138	0	
11	POL	POL	POL	POL	0	
12	POL	POL	POL	POL	0	
13	POL	POL	POL	POL	0	
14	POL	POL	POL	POL	0	
15	26	55.7	Y	17,982	0	
16	26	56	Y	6,993	0	
17	26	56.2	Y	9,343	0	
18	POL	POL	POL	POL	0	
19	POL	POL	POL	POL	0	
20	POL	POL	POL	POL	0	
21	POL	POL	POL	POL	0	
22	26	55.1	Y	17,640	0	
23	26	56.5	Y	14,700	0	
24	POL	POL	POL	POL	0	
25	26	55.7	Y	8,780	0	
26	POL	POL	POL	POL	0	
27	POL	POL	POL	POL	0	
28	26	54.6	Y	15,568	0	
29	26	54.8	Y	15,568	0	
30	POL	POL	POL	POL	0	
31	26	57.2	Y	17,517	0	
Monthly Cumulative % Off-Spec Water Produced						0

Signature: Op Cert #: 7232Date: 8-8-25