

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: CURRY

Conventional or Direct Filtration

Month/Year: Oct. 2025

System Name: Rainbow Rock Service Association		ID#: 41		01361		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.14	0.15	POL	POL	POL	POL	0.15
2	POL	POL	0.12	0.12	POL	POL	0.12
3	POL	POL	POL	POL	POL	POL	
4	POL	POL	POL	POL	POL	POL	
5	POL	POL	POL	POL	POL	POL	
6	POL	POL	0.14	0.08	0.08	0.09	0.14
7	0.09	0.08	0.07	POL	POL	POL	0.09
8	POL	POL	POL	POL	POL	POL	
9	POL	POL	POL	POL	POL	POL	
10	POL	POL	POL	POL	POL	POL	
11	POL	POL	POL	POL	POL	POL	
12	POL	POL	POL	POL	POL	POL	
13	POL	POL	POL	0.09	0.09	0.08	0.09
14	0.08	0.08	0.07	0.07	POL	POL	0.08
15	POL	POL	POL	POL	POL	POL	
16	POL	POL	0.09	POL	POL	POL	0.09
17	POL	POL	POL	POL	POL	POL	
18	POL	POL	POL	POL	POL	POL	
19	POL	POL	POL	POL	POL	POL	
20	POL	POL	POL	POL	POL	POL	
21	POL	POL	POL	0.07	0.06	0.05	0.07
22	0.05	0.05	0.05	0.05	0.05	POL	0.05
23	POL	POL	POL	POL	POL	POL	
24	POL	POL	POL	POL	POL	POL	
25	POL	POL	POL	POL	POL	POL	
26	POL	POL	POL	POL	POL	POL	
27	POL	POL	POL	POL	POL	POL	
28	POL	POL	POL	POL	POL	POL	
29	POL	POL	POL	POL	POL	POL	
30	POL	POL	0.06	0.05	0.05	0.06	0.06
31	0.06	0.06	0.06	0.04	0.04	POL	0.06

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?

Yes/No

All 4-hour turbidity readings $\leq$ 1 NTU?

Yes/No

All turbidity readings < IFE² triggers

Yes/No

CT's met everyday?
(see back)

Yes/No

All Cl₂ residual at entry point
 $\geq$ 0.2 mg/l?

Yes/No

Notes:

PRINTED NAME: Jonathan Woody

SIGNATURE:

DATE: 11-10-25

PHONE #: (541) 643-6137

CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

A

System Name:	Rainbow Rock Service Association	ID#: 41	01361	Month/Year:	Disinfection <i>Giardia</i> Log Inactiv:	1
--------------	----------------------------------	---------	-------	-------------	---	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.62	71	44.0	16.2	7.18	25.7	YES	20
2	POL	71	POL	POL	POL	POL	POL	20
3	0.68	71	48.3	16.1	7.40	28.3	YES	20
4	POL	71	POL	POL	POL	POL	POL	20
5	POL	71	POL	POL	POL	POL	POL	20
6	0.75	71	53.3	16.6	7.15	25.1	YES	20
7	0.66	71	46.9	15.0	7.44	30.8	YES	20
8	POL	71	POL	POL	POL	POL	POL	20
9	POL	71	POL	POL	POL	POL	POL	20
10	POL	71	POL	POL	POL	POL	POL	20
11	POL	71	POL	POL	POL	POL	POL	20
12	POL	71	POL	POL	POL	POL	POL	20
13	0.62	71	44.0	14.0	6.92	27.1	YES	20
14	1.52	71	107.9	14.2	7.04	30.9	YES	20
15	POL	71	POL	POL	POL	POL	POL	20
16	1.66	71	117.9	13.8	7.00	31.8	YES	20
17	POL	71	POL	POL	POL	POL	POL	20
18	POL	71	POL	POL	POL	POL	POL	20
19	POL	71	POL	POL	POL	POL	POL	20
20	POL	71	POL	POL	POL	POL	POL	20
21	1.92	71	136.3	13.8	7.11	34.1	YES	20
22	0.94	71	66.7	13.8	7.17	31.2	YES	20
23	POL	71	POL	POL	POL	POL	POL	20
24	POL	71	POL	POL	POL	POL	POL	20
25	POL	71	POL	POL	POL	POL	POL	20
26	POL	71	POL	POL	POL	POL	POL	20
27	POL	71	POL	POL	POL	POL	POL	20
28	POL	71	POL	POL	POL	POL	POL	20
29	POL	71	POL	POL	POL	POL	POL	20
30	1.15	71	81.7	13.7	7.18	32.3	YES	20
31	1.98	71	140.6	13.3	7.25	37.4	YES	20

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013

Month/Year: Oct. 2025

Minimum Validated UVT : 75%

rev 1/11 I:\MC\forms\Turbidity Report Form – UV and opt mod.doc

Date: 11-7-25