

**OHA - Drinking Water Services -Turbidity Monitoring Report Form**  
**Conventional or Direct Filtration**

County: **CURRY**  
 Month/Year: **Nov-25**

**System Name:** Rainbow Rock Service Association    **ID#: 41**    **01361**    **WTP: TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	POL	POL	POL	POL	POL	POL	
2	POL	POL	POL	POL	POL	POL	
3	POL	POL	POL	POL	POL	POL	
4	POL	POL	POL	0.06	0.05	POL	0.06
5	POL	POL	POL	POL	POL	POL	
6	POL	POL	POL	POL	POL	POL	
7	POL	POL	POL	POL	POL	POL	
8	POL	POL	POL	POL	POL	POL	
9	POL	POL	POL	POL	POL	POL	
10	POL	POL	POL	POL	POL	POL	
11	POL	POL	POL	POL	POL	0.04	0.04
12	0.04	0.04	0.04	0.04	0.04	0.04	0.04
13	0.04	0.04	POL	POL	POL	POL	0.04
14	POL	POL	0.05	0.05	0.05	POL	0.05
15	POL	POL	POL	POL	POL	POL	
16	POL	POL	POL	POL	POL	POL	
17	POL	POL	POL	POL	POL	POL	
18	POL	POL	0.08	0.06	0.05	0.04	0.08
19	0.04	0.04	0.04	0.04	0.04	POL	0.04
20	POL	POL	POL	POL	POL	POL	
21	POL	POL	POL	POL	POL	POL	
22	POL	POL	POL	POL	POL	POL	
23	POL	POL	POL	POL	POL	POL	
24	POL	POL	POL	POL	POL	POL	
25	POL	POL	0.06	0.05	0.05	0.05	0.06
26	0.05	0.05	0.05	0.05	0.05	0.05	0.05
27	0.06	0.06	POL	POL	POL	POL	0.06
28	POL	POL	POL	POL	POL	POL	
29	POL	POL	POL	POL	POL	POL	
30	POL	POL	POL	POL	POL	POL	
31	POL	POL	POL	POL	POL	POL	

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <span style="float:right"><u>Yes</u> / No</span>	CT's met everyday? (see back) <span style="float:right"><u>Yes</u> / No</span>	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <span style="float:right"><u>Yes</u> / No</span>
All 4-hour turbidity readings ≤ 1 NTU? <span style="float:right"><u>Yes</u> / No</span>		
All turbidity readings < IFE <sup>2</sup> triggers <span style="float:right"><u>Yes</u> / No</span>		

**Notes:**

<b>PRINTED NAME:</b> Jonathan Woody
<b>SIGNATURE:</b> <i>Jonathan Woody</i>
<b>PHONE #:</b> ( 541 ) 643-6137
<b>DATE:</b> 12-8-25
<b>CERT #:</b> 7232

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Rainbow Rock Service Association ID#: 41 01361 Month/Year: Nov-25 Disinfection *Giardia* Log Inactiv: 1

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	POL	71	POL	POL	POL	POL	POL	20
2	POL	71	POL	POL	POL	POL	POL	20
3	POL	71	POL	POL	POL	POL	POL	20
4	1.2	71	85.2	14.4	6.95	28.5	YES	20
5	POL	71	POL	POL	POL	POL	POL	20
6	POL	71	POL	POL	POL	POL	POL	20
7	POL	71	POL	POL	POL	POL	POL	20
8	POL	71	POL	POL	POL	POL	POL	20
9	POL	71	POL	POL	POL	POL	POL	20
10	POL	71	POL	POL	POL	POL	POL	20
11	1.46	71	103.7	13.4	7.01	32.1	YES	20
12	1.08	71	76.7	13.7	7.08	30.9	YES	20
13	1.09	71	77.4	14.2	7.28	32.2	YES	20
14	1.52	71	107.9	14.6	7.10	30.8	YES	20
15	POL	71	POL	POL	POL	POL	POL	20
16	POL	71	POL	POL	POL	POL	POL	20
17	POL	71	POL	POL	POL	POL	POL	20
18	1.89	71	134.2	13.6	6.90	31.9	YES	20
19	1.06	71	75.3	12.6	7.25	35.3	YES	20
20	POL	71	POL	POL	POL	POL	POL	20
21	POL	71	POL	POL	POL	POL	POL	20
22	POL	71	POL	POL	POL	POL	POL	20
23	POL	71	POL	POL	POL	POL	POL	20
24	POL	71	POL	POL	POL	POL	POL	20
25	0.78	71	55.4	11.8	7.20	35.9	YES	20
26	1.06	71	75.3	11.5	7.22	38.0	YES	20
27	0.68	71	48.3	11.6	7.21	36.1	YES	20
28	POL	71	POL	POL	POL	POL	POL	20
29	POL	71	POL	POL	POL	POL	POL	20
30	POL	71	POL	POL	POL	POL	POL	20
31	POL	71	POL	POL	POL	POL	POL	20

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013

# Oregon DHS - Drinking Water Services – Surface Water Quality Data

System Name: Rainbow Rock Service Association ID# 41 01361 Month/Year: Nov / 2025  
 Minimum UVT [%] during month: 88 Duty sensor variation from reference sensor %: 0%  
 Minimum Validated UVT : 75%

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm/unit]	[ <sup>mW</sup> /cm <sup>2</sup> ]	[ Y or N ]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	POL	POL	POL	POL	0	
2	POL	POL	POL	POL	0	
3	POL	POL	POL	POL	0	
4	20	54.8	Y	9,466	0	
5	POL	POL	POL	POL	0	
6	POL	POL	POL	POL	0	
7	POL	POL	POL	POL	0	
8	POL	POL	POL	POL	0	
9	POL	POL	POL	POL	0	
10	POL	POL	POL	POL	0	
11	20	48.6	Y	3,432	0	
12	20	48.6	Y	13,728	0	
13	20	40.7	Y	4,004	0	
14	20	42.8	Y	10,385	0	
15	POL	POL	POL	POL	0	
16	POL	POL	POL	POL	0	
17	POL	POL	POL	POL	0	
18	20	45	Y	9,104	0	
19	20	42.4	Y	9,673	0	
20	POL	POL	POL	POL	0	
21	POL	POL	POL	POL	0	
22	POL	POL	POL	POL	0	
23	POL	POL	POL	POL	0	
24	POL	POL	POL	POL	0	
25	20	54.9	Y	10,296	0	
26	20	54	Y	13,728	0	
27	20	45.8	Y	5,148	0	
28	POL	POL	POL	POL	0	
29	POL	POL	POL	POL	0	
30	POL	POL	POL	POL	0	
31	POL	POL	POL	POL	0	
Monthly Cumulative % Off-Spec Water Produced						0

Signature: *John Wherry*

Op Cert #: 7232

Date: 12-8-25