

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Josephine
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: GALICE SUBDIVISION WATER CO ID #: OR4101424 WTP:- WTP-A Month/Year:

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1						0.80	0.80
2			0.76				0.76
3				0.59			0.59
4			0.48				0.48
5			0.44				0.44
6			0.41				0.41
7			0.40				0.40
8					0.40		0.40
9						0.39	0.39
10						0.39	0.39
11				0.39			0.39
12				0.39			0.39
13				0.40			0.40
14					0.42		0.42
15			0.45				0.45
16						0.41	0.41
17			0.39				0.39
18						0.40	0.40
19			0.40				0.40
20						0.39	0.39
21						0.39	0.39
22					0.39		0.39
23						0.39	0.39
24						0.39	0.39
25			0.39				0.39
26			0.39				0.39
27			0.39				0.39
28			0.39				0.39
29							
30							
31							

Slow Sand/Membrane/DE Filtration/ Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ² Yes / No	CT's met everyday? (see back) Yes / No	All Cl ₂ residual at entry point \geq 0.2 mg/l? Yes / No	
All daily turbidity readings \leq 5 NTU? Yes / No			
Notes:	PRINTED NAME: L. D. PATTERSON		
	SIGNATURE: <i>L.D. Patterson</i>	DATE: 3/6/2021	
	PHONE #: (541) 476-6555	CERT #: JOSEPHINE	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

GALICE SUBDIVISION WATER CO ID #: OR4101424 WTP.: WTP-A Month/Year: FEBRUARY 2021

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
(2P) (2M) (2H) (2A)	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/10P	0.47	unknown	unknown	8.4°	7.8	204	YES	
2/8A	0.51			8.1°	7.8	204		
3/2P	0.45			7.9°	7.8	204		
4/9A	0.74			8.1°	7.8	210		
5/8A	0.83			8.6°	7.8	216		
6/11P	1.10			8.3°	7.8	221		
7/11A	0.95			7.3°	7.8	216		
8/4P	0.83			8.8°	7.8	216		
9/10P	0.51			8.1°	7.8	204		
10/10P	0.67			8.2°	7.8	210		
11/1P	1.07			8.4°	7.8	221		
12/12P	1.27			9.3°	7.8	227		
13/3P	1.17			9.3°	7.8	221		
14/6P	0.83			9.1°	7.8	216		
15/8A	0.69			8.9°	7.8	210		
16/10P	0.59			9.2°	7.8	204		
17/10A	1.26			9.1°	7.8	227		
18/11P	1.04			9.1°	7.8	221		
19/11A	1.29			7.9°	7.8	227		
20/8P	0.95			8.0°	7.8	216		
21/11P	0.93			7.9°	7.8	216		
22/6P	0.66			8.1°	7.8	210		
23/8P	0.43			7.9°	7.8	204		
24/10P	0.61			8.3°	7.8	210		
25/9A	1.02			8.1°	7.8	221		
26/9A	1.64			8.3°	7.8	238		
27/10A	1.37			8.1°	7.8	227		
28/10A	1.26			7.9°	7.8	227		
29/								
30/								
31/								

³If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.