

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Josephine
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: GALICE SUBDIVISION WATER CO ID #: OR4101424 WTP-: WTP-A Month/Year: **MARCH 2021**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1						0.39	0.39
2			0.39				0.39
3				0.39			0.39
4			0.39				0.39
5			0.39				0.39
6						0.40	0.40
7						0.41	0.41
8					0.40		0.40
9					0.39		0.39
10			0.39				0.39
11			0.39				0.39
12			0.39				0.39
13			0.39				0.39
14					0.40		0.40
15			0.40				0.40
15			0.38			0.40	0.40
17			0.38				0.38
18						0.39	0.39
19			0.39				0.39
20			0.39				0.39
21			0.39				0.39
22			0.39				0.39
23			0.39				0.39
24			0.39				0.39
25			0.39				0.39
26					0.39		0.39
27				0.39			0.39
28			0.39				0.39
29						0.39	0.39
30			0.38				0.38
31					0.38		0.38

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	
All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	Notes:		
PRINTED NAME: L.D. Patterson		DATE: 4/6/2021	
SIGNATURE: <i>[Signature]</i>		CERT #: JOSEPHINE	
PHONE #: (941) 476-6555			

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

GALICE SUBDIVISION WATER CO ID #: OR4101424 WTP: WTP-A Month/Year: **MARCH 2021**

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
12P=NOON	[ppm or mg/L]	(minutes)	CXT	[°C]		Use tables	Yes / No	[GPM]
1/8P	0.72	unknown	unknown	8.1°C	7.8	210	YES	
2/10A	0.60			8.1°C	7.8	204		
3/2P	0.55			7.5°C	7.8	204		
4/9A	0.56			8.4°C	7.8	204		
5/9A	1.25			8.1°C	7.8	227		
6/10P	1.30			8.3°C	7.8	227		
7/10P	1.27			8.1°C	7.8	227		
8/4P	1.18			8.0°C	7.8	221		
9/6P	1.09			7.8°C	7.8	221		
10/11A	0.84			7.9°C	7.8	216		
11/9A	1.04			7.8°C	7.8	221		
12/10A	0.92			8.5°C	7.8	216		
13/10A	0.76			8.5°C	7.8	210		
14/7P	0.54			8.6°C	7.8	204		
15/11A	0.47			8.0°C	7.8	204		
16/11P	1.37			8.3°C	7.8	227		
17/9A	1.28			7.9°C	7.8	227		
18/11P	1.34			8.3°C	7.8	227		
19/8A	1.24			8.1°C	7.8	227		
20/8A	1.16			8.2°C	7.8	221		
21/8A	0.97			8.4°C	7.8	216		
22/10A	0.51			8.6°C	7.8	204		
23/9A	1.08			8.9°C	7.8	221		
24/8A	1.47			9.0°C	7.8	232		
25/8A	1.51			9.4°C	7.8	232		
26/5P	1.08			8.6°C	7.8	221		
27/12P	0.71			9.0°C	7.8	210		
28/10A	0.46			9.8°C	7.8	204		
29/9P	1.65			9.3°C	7.8	238		
30/9A	1.57			9.4°C	7.8	232		
31/7P	1.13	↓	↓	9.9°C	7.8	221	↓	

³If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.