

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Josephine
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems



System Name: GALICE SUBDIVISION WATER CO ID #: OR4101424 WTP-: WTP-A Month/Year: **APRIL, 2021**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1			0.39				0.39
2			0.39				0.39
3						0.39	0.39
4			0.38				0.38
5			0.38				0.38
6						0.39	0.39
7			0.39				0.39
8		0.39					0.39
9			0.38				0.38
10				0.38			0.38
11						0.39	0.39
12				0.40			0.40
13			0.40				0.40
14			0.46				0.46
15			0.42				0.42
16			0.41				0.41
17						0.40	0.40
18			0.40				0.40
19						0.46	0.46
20			0.39				0.39
21			0.40				0.40
22			0.40				0.40
23						0.39	0.39
24			0.41				0.41
25						0.40	0.40
26						0.39	0.39
27			0.40				0.40
28						0.39	0.39
29				0.39			0.39
30			0.40				0.40
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes / No	CT's met everyday? (see back) Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes / No	
All daily turbidity readings ≤ 5 NTU? Yes / No			
Notes:	PRINTED NAME: L.D. PATTERSON		DATE: MAY 4, 2021
	SIGNATURE: <i>[Signature]</i>		CERT #: Josephine
	PHONE #: (541) 476-6555		

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

GALICE SUBDIVISION WATER CO ID #: OR4101424 WTP: WTP-A Month/Year: APRIL 2021

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
12P=NOON	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/8A	0.91	unknown	unknown	10.1°C	7.8	162	YES	unknown
2/8A	0.69			10.5°C	7.8	158		
3/9P	0.61			10.6°C	7.8	158		
4/9A	0.65			11.0°C	7.8	158		
5/8A	0.68			11.5°C	7.8	158		
6/9P	0.64			10.2°C	7.8	158		
7/8A	0.65			10.9°C	7.8	158		
8/7A	0.47			10.6°C	7.8	153		
9/9A	0.59			10.3°C	7.8	153		
10/3P	0.51			10.8°C	7.8	153		
11/8P	0.41			11.1°C	7.8	153		
12/2P	0.72			10.9°C	7.8	153		
13/8A	0.94			11.0°C	7.8	162		
14/10A	0.65			10.1°C	7.8	158		
15/8A	0.46			11.1°C	7.8	153		
16/8A	0.45			12.1°C	7.8	153		
17/8P	0.78			12.0°C	7.8	158		
18/8A	0.89			12.6°C	7.8	162		
19/8P	0.85			12.8°C	7.8	162		
20/8A	0.73			12.8°C	7.8	158		
21/8A	0.54			12.6°C	7.8	153		
22/8A	0.49			12.9°C	7.8	153		
23/9P	0.51			12.0°C	7.8	153		
24/8A	0.56			12.1°C	7.8	153		
25/8P	0.51			12.4°C	7.8	153		
26/11P	0.53			12.4°C	7.8	153		
27/8A	0.41			11.0°C	7.8	153		
28/10P	0.84			13.2°C	7.8	162		
29/11P	0.77			13.0°C	7.8	158		
30/9A	0.64			12.6°C	7.8	158		
31/								

³If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.