

**OHA - Drinking Water Program - Turbidity Monitoring Report Form** County: Josephine  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: GALICE SUBDIVISION WATER CO ID #: OR4101424 WTP: WTP-A Month/Year: MAY 2021

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1			0.40				0.40
2			0.39				0.39
3						0.40	0.40
4			0.40				0.40
5						0.39	0.39
6			0.39				0.39
7			0.40				0.40
8			0.39				0.39
9					0.39		0.39
10						0.40	0.40
11			0.39				0.39
12			0.46				0.46
13						0.41	0.41
14						0.41	0.41
15						0.41	0.41
16						0.40	0.40
17			0.41				0.41
18			0.39				0.39
19			0.40				0.40
20			0.41				0.41
21						0.41	0.41
22			0.41				0.41
23			0.40				0.40
24			0.40				0.40
25						0.40	0.40
26			0.40				0.40
27			0.40				0.40
28			0.39				0.39
29			0.40				0.40
30			0.40				0.40
31			0.39				0.39

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> Yes / No All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	Monthly Summary (Answer Yes or No)	
	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
Notes:	PRINTED NAME: <u>L.D. PATTERSON</u>	
	SIGNATURE: <u>L.D. Patterson</u>	DATE: <u>6/3/2021</u>
	PHONE #: <u>(541) 476-6555</u>	CERT #: <u>Josephine</u>

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

GALICE SUBDIVISION WATER CO ID #: OR4101424 WTP: WTP-A Month/Year: MAY 2021

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT'	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
119A	0.51	Unknown	Unknown	13.3°C	7.8	153	YES	
218A	0.42			14.1°C	7.8	153		
310P	0.61			13.4°C	7.8	158		
418A	0.72			12.9°C	7.8	158		
511P	0.53			14.4°C	7.8	153		
618A	0.46			13.8°C	7.8	153		
719A	0.59			13.5°C	7.8	153		
819A	0.63			13.1°C	7.8	158		
915P	0.55			13.3°C	7.8	153		
1010P	0.66			14.0°C	7.8	158		
1118A	0.52			13.4°C	7.8	153		
1218A	0.56			13.3°C	7.8	153		
1319P	0.43			15.2°C	7.8	102		
1411P	0.77			16.2°C	7.8	105		
1519P	0.96			15.3°C	7.8	108		
1619P	0.67			15.4°C	7.8	105		
1719A	0.44			14.6°C	7.8	153		
1819A	0.87			15.4°C	7.8	108		
1919A	0.67			13.2°C	7.8	158		
2018A	0.43			13.6°C	7.8	153		
2118P	0.59			14.1°C	7.8	153		
2218A	0.71			13.6°C	7.8	158		
2318A	0.67			13.4°C	7.8	158		
2418A	0.59			13.8°C	7.8	153		
2518P	0.53			14.2°C	7.8	153		
2618A	0.62			12.9°C	7.8	158		
27110A	0.72			13.5°C	7.8	158		
2819A	0.64			13.1°C	7.8	158		
2919A	0.69			13.4°C	7.8	158		
3019A	0.68			14.3°C	7.8	158		
3118A	0.47			15.1°C	7.8	102		

<sup>3</sup>If Cl<sub>2</sub> at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.