

OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Josephine
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: GALICE SUBDIVISION WATER CO ID #: OR4101424 WTP: WTP-A Month/Year: July 2021

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1			0.39				0.39
2						0.39	0.39
3			0.39				0.39
4			0.39				0.39
5			0.38				0.38
6			0.39				0.39
7			0.39				0.39
8			0.38				0.38
9			0.39				0.39
10						0.39	0.39
11			0.38				0.38
12					0.39		0.39
13					0.39		0.39
14						0.38	0.38
15						0.39	0.39
16						0.38	0.38
17			0.39				0.39
18						0.38	0.38
19			0.39				0.39
20			0.39				0.39
21						0.38	0.38
22				0.38			0.38
23				0.39			0.39
24					0.38		0.38
25						0.39	0.39
26			0.38				0.38
27						0.39	0.39
28						0.38	0.38
29			0.39				0.39
30			0.38				0.38
31					0.39		0.39

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes / No	Yes / No	CT's met everyday? (see back) Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes / No
All daily turbidity readings ≤ 5 NTU?	Yes / No		
Notes:	PRINTED NAME: L.D. PATTERSON		DATE: 8/2/2021
	SIGNATURE: [Signature]		CERT #: Josephine
	PHONE #: (541) 476-6555		

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

GALICE SUBDIVISION WATER CO ID #: OR4101424 WTP: WTP-A Month/Year: JULY 2021

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
12P=NOON	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
119A	0.72	UNKNOWN	UNKNOWN	19.2°	7.8	105	YES	unknown
211P	0.47			21.2°	7.8	77		
319A	0.51			21.3°	7.8	77		
419A	0.69			21.1°	7.8	79		
519A	0.81			20.2°	7.8	81		
618A	0.43			20.6°	7.8	77		
718A	1.03			18.3°	7.8	111		
818A	0.71			18.6°	7.8	105		
919P	0.94			20.6°	7.8	81		
1010P	0.61			20.8°	7.8	79		
1110A	0.46			19.8°	7.8	102		
1216P	1.10			20.4°	7.8	83		
1316P	0.70			20.2°	7.8	79		
1411P	1.17			20.4°	7.8	83		
1510P	0.42			20.9°	7.8	77		
1619P	0.81			20.1°	7.8	81		
1710A	1.09			19.9°	7.8	111		
1811P	1.04			19.7°	7.8	111		
1919A	1.01			18.7°	7.8	111		
2018A	0.78			18.4°	7.8	105		
2110P	0.57			19.7°	7.8	102		
2211P	0.78			20.5°	7.8	79		
2311P	0.52			18.4°	7.8	102		
2416P	0.79			19.6°	7.8	105		
2519P	0.58			21.1°	7.8	77		
2619A	0.45			20.6°	7.8	77		
2710P	0.65			19.9°	7.8	105		
2811P	0.52			21.3°	7.8	77		
2911A	0.54			19.3°	7.8	102		
3010A	0.59			20.0°	7.8	77		
3116P	0.5	✓	✓	21.1°	7.8	77	✓	✓

³If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.