

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Josephine
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: GALICE SUBDIVISION WATER CO ID #: OR4101424 WTP:- WTP-A Month/Year: AUGUST 2021

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1		0.39					0.39
2		0.38					0.38
3						0.38	0.38
4						0.39	0.39
5			0.39				0.39
6			0.39				0.39
7			0.38			0.38	0.38
8						0.39	0.39
9			0.38				0.38
10			0.39				0.39
11						0.38	0.38
12						0.39	0.39
13						0.38	0.38
14						0.38	0.38
15			0.39				0.39
16						0.39	0.39
17			0.39				0.39
18			0.38				0.38
19			0.38				0.38
20			0.39				0.39
21			0.38				0.38
22			0.39				0.39
23			0.38				0.38
24			0.38				0.38
25			0.39				0.39
26			0.39				0.39
27			0.38				0.38
28			0.38				0.38
29						0.39	0.39
30						0.39	0.39
31			0.38				0.38

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ² Yes / No	All daily turbidity readings \leq 5 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residual at entry point \geq 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
Notes:		PRINTED NAME: <u>L.D. PATTERSON</u>	DATE: <u>9/2/2021</u>
		SIGNATURE: <u>LD Patterson</u>	CERT #: <u>JOSEPHINE</u>
		PHONE #: <u>(541) 476-6555</u>	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program – Surface Water Quality Data Form

GALICE SUBDIVISION WATER CO. ID #: OR4101424 WTP.: WTP-A Month/Year: **AUGUST 2021**

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
117A	0.77	unknown	unknown	20.8°C	7.8	79	YES	unknown
217A	0.44			19.7°C	7.8	102		
3110P	0.51			21.1°C	7.8	77		
4111P	0.66			21.2°C	7.8	79		
519A	0.73			20.3°C	7.8	79		
619A	0.71			19.8°C	7.8	105		
719A	0.68			19.5°C	7.8	105		
818P	0.74			19.1°C	7.8	105		
919A	0.89			18.6°C	7.8	108		
1019A	0.51			19.4°C	7.8	102		
1110P	0.73			20.2°C	7.8	79		
1210P	0.71			20.9°C	7.8	79		
1319P	0.66			20.9°C	7.8	79		
1410P	0.74			21.5°C	7.8	79		
1514P	1.03			21.0°C	7.8	83		
1619A	0.64			19.8°C	7.8	105		
1719P	0.71			20.3°C	7.8	79		
1819A	0.98			17.6°C	7.8	108		
1919A	1.09			18.9°C	7.8	111		
2019A	1.05			19.2°C	7.8	111		
2119A	0.72			18.4°C	7.8	105		
2219A	0.44			18.1°C	7.8	102		
2318A	0.93			17.4°C	7.8	108		
24110A	0.93			16.8°C	7.8	108		
25110A	0.73			16.9°C	7.8	105		
26110A	1.16			17.1°C	7.8	111		
27110A	0.69			17.4°C	7.8	105		
2818A	0.43			17.8°C	7.8	102		
29111P	0.67			18.6°C	7.8	105		
3019P	0.72			18.5°C	7.8	105		
3119A	0.61			17.2°C	7.8	105		

³If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.