

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Josephine
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: GALICE SUBDIVISION WATER CO ID #: OR4101424 WTP: WTP-A Month/Year: OCTOBER / 2021

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1			0.39				0.39
2						0.39	0.39
3						0.38	0.38
4			0.39				0.39
5			0.39				0.39
6				0.38			0.38
7		0.38					0.38
8			0.39				0.39
9						0.38	0.38
10						0.38	0.38
11						0.38	0.38
12						0.38	0.38
13		0.38					0.38
14						0.38	0.38
15		0.38					0.38
16			0.39			0.39	0.39
17						0.38	0.38
18			0.39				0.39
19			0.38				0.38
20						0.38	0.38
21						0.39	0.39
22			0.51				0.51
23			0.44				0.44
24			0.42				0.42
25			0.40				0.40
26						0.42	0.42
27			0.43				0.43
28			0.40				0.40
29			0.40				0.40
30			0.44				0.44
31						0.42	0.42

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ² Yes / No All daily turbidity readings \leq 5 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residual at entry point \geq 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
Notes:	PRINTED NAME: L. D. PATTERSON	
	SIGNATURE: <i>[Signature]</i>	DATE: 11/2/21
	PHONE #: (541) 476-6555	CERT #: JOSEPHINE

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program – Surface Water Quality Data Form

GALICE SUBDIVISION WATER CO ID #: OR4101424 WTP.: WTP-A Month/Year: OCTOBER / 2021

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/9A	0.51	unknown	unknown	15.1°C	7.8	102	YES	unknown
2/10P	0.47			14.9°C	7.8	153		
3/9P	0.61			15.3°C	7.8	105		
4/10A	0.63			14.3°C	7.8	158		
5/8A	0.54			14.8°C	7.8	153		
6/3P	0.42			14.2°C	7.8	153		
7/7A	0.43			14.1°C	7.8	153		
8/8A	0.42			13.8°C	7.8	153		
9/11P	0.68			13.6°C	7.8	158		
10/11P	0.93			13.3°C	7.8	162		
11/11P	0.67			13.1°C	7.8	158		
12/11P	0.52			12.8°C	7.8	153		
13/11A	0.46			12.6°C	7.8	153		
14/11P	0.49			12.5°C	7.8	153		
15/10A	0.73			12.7°C	7.8	158		
16/9A	0.82			12.7°C	7.8	162		
17/8P	0.72			12.8°C	7.8	158		
18/9A	0.62			12.6°C	7.8	158		
19/9A	0.66			12.3°C	7.8	158		
20/10P	0.42			13.1°C	7.8	153		
21/10P	0.51			13.2°C	7.8	153		
22/11A	0.61			12.8°C	7.8	158		
23/10A	0.58			12.6°C	7.8	153		
24/10A	0.43			12.8°C	7.8	153		
25/9A	0.42			12.9°C	7.8	153		
26/9P	0.49			12.7°C	7.8	153		
27/9A	1.56			12.3°C	7.8	174		
28/9A	1.62			13.0°C	7.8	179		
29/9A	1.46			13.3°C	7.8	174		
30/10A	1.33			13.6°C	7.8	170		
31/9P	0.45	↓	↓	13.8°C	7.8	153	↓	↓

³If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.
 Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/lurb-alt-unfiltered.pdf