

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Josephine
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: GALICE SUBDIVISION WATER CO ID #: OR4101424 WTP-: WTP-A Month/Year:

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1						0.42	0.42
2			.40				0.40
3			.40				0.40
4			.47			0.42	0.42
5						0.42	0.42
6						0.42	0.42
7			0.43				0.43
8			0.42				0.42
9			0.39				0.39
10			0.40				0.40
11			0.40				0.40
12			0.38				0.38
13				0.39			0.39
14					0.48		0.48
15					0.42		0.42
16				0.41	0.40		0.41
17					0.40		0.40
18					0.48		0.48
19				0.52			0.52
20					0.42		0.42
21					0.42		0.42
22					0.47		0.47
23				0.45			0.45
24					0.40		0.40
25					0.44		0.44
26					0.46		0.46
27					0.43		0.43
28					0.45		0.45
29					0.48		0.48
30					0.41		0.41
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes / No	CT's met everyday? (see back) Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes / No	
All daily turbidity readings ≤ 5 NTU? Yes / No			
Notes:		PRINTED NAME: <i>William C. Tarr</i>	DATE: <i>12/1/21</i>
		SIGNATURE: <i>W.C. Tarr DC</i>	CERT #: <i>Josephine</i>
		PHONE #: <i>(541) 471-7004</i>	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program – Surface Water Quality Data Form

GALICE SUBDIVISION WATER CO ID #: OR4101424 WTP-: WTP-A Month/Year:

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
11/0pm	0.46	unknown	unknown	13.6°	7.8	153	Yes	unknown
21/0am	0.76			13.7°	7.8	158		
31/0am	1.22			13.1°	7.8	130		
41/9am	0.71			13.9°	7.8	158		
51/8am	1.18			13.8°	7.8	166		
61/9pm	0.53			12.9°	7.8	153		
71/0am	0.79			12.6°	7.8	158		
81/0am	0.98			12.2°	7.8	162		
91/0am	0.84			11.8°	7.8	162		
101/9am	0.91			11.6°	7.8	162		
111/8am	1.27			11.5°	7.8	170		
121/0am	1.38			12.2°	7.8	170		
131/3pm	1.48			12.9°	7.8	174		
141/4pm	1.17			14.3°	7.8	166		
151/4pm	1.38			14.7°	7.8	170		
161/2pm	1.28			13.9°	7.8	170		
171/5pm	1.46			11.5°	8.2	174		
181/4pm	1.29			15.6°	7.8	114		
191/8pm	1.07			15.4°	7.8	111		
201/4pm	1.03			14.7°	7.8	166		
211/4pm	1.02			14.6°	7.8	166		
221/4pm	0.88			15.0°	7.8	162		
231/2pm	1.01			14.4°	7.8	166		
241/6pm	1.25			10.6°	7.8	170		
251/4:30	1.32			11.5°	7.8	170		
261/5pm	1.31			11.9°	7.8	170		
271/5pm	1.28			11.3°	7.8	170		
281/3:30	0.94			12.8°	7.8	162		
291/5pm	1.27			13.1°	7.8	170		
301/3pm	1.38			13.1°	7.8	170		
31/								

³If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.

Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-all-unfiltered.pdf