

~~January~~
December 2021

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Josephine
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: GALICE SUBDIVISION WATER CO ID #: OR4101424 WTP: WTP-A Month/Year:

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1					0.43		0.43
2					0.50		0.50
3					0.60		0.60
4					0.58		0.58
5						0.48	0.48
6						0.46	0.46
7						0.48	0.48
8						0.46	0.46
9					0.55		0.55
10					0.50		0.50
11					0.44		0.44
12					0.70		0.70
13						0.64	0.64
14						0.70	0.70
15					0.67		0.67
16					0.52		0.52
17						0.65	0.65
18						0.96	0.96
19						0.48	0.48
20						0.64	0.64
21						0.65	0.65
22						0.59	0.59
23						0.77	0.77
24						0.66	0.66
25						0.65	0.65
26						0.50	0.50
27					0.51		0.51
28					0.45		0.45
29					0.56		0.56
30					0.85		0.85
31						0.60	0.60

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="checkbox"/> Yes / No All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / No		CT's met everyday? (see back) Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes / No
Notes:		PRINTED NAME: William Tarr	
		SIGNATURE: <i>William Tarr</i>	DATE: 1/4/22
		PHONE #: 541-1471-7004	CERT #: Josephine

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

December
2021

OHA - Drinking Water Program - Surface Water Quality Data Form

GALICE SUBDIVISION WATER CO ID #: OR4101424 WTP: WTP-A Month/Year:

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
114pm	1.49	unknown	unknown	12.9	7.8	174	Yes	unknown
214pm	1.50			12.9	7.8	174		
315pm	1.54			12.9	7.8	174		
414pm	1.34			12.6	7.5	170		
515pm	1.38			12.1	7.6	170		
613pm	1.11			12.1	7.6	166		
715pm	.61			13.0	7.6	158		
815pm	.55			12.6	7.6	149		
914pm	.35			11.6	7.7	149		
1014pm	.42			12.1	7.5	149		
1112pm	.95			11.9	7.6	142		
1215pm	.22			12.1	7.5	149		
1315pm	.21			10.7	7.7	149		
1418pm	.12			9.6	7.7	149		
1513pm	.07			8.5	7.7	149		
1613pm	.07			9.3	7.8	149		
1718pm	1.62			9.4	7.7	179		
1815pm	.24			9.7	7.4	149		
1915pm	.12			10.0	7.4	149		
2010pm	.24			9.7	7.8	149		
2114pm	0.19			12.6	7.5	149		
2215pm	2.00			10.0	7.4	182		
2316pm	.08			10.3	7.4	158		
2418pm	.02			10.6	7.4	149		
2515pm	.00			11.0	7.3	149		
2615pm	2.00			9.6	7.8	182		
2714pm	.98			10.2	7.5	162		
2814pm	.80			9.9	7.7	158		
2914pm	.62			10.4	7.8	158		
3014pm	.23			10.4	7.8	149		
3115pm	.46			10.4	7.9	153		

³If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.