

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Josephine**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: GALICE SUBDIVISION WATER CO ID #: OR4101424 WTP-: WTP-A Month/Year:

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1					0.57		0.57
2					0.45		0.45
3					.78		0.78
4					.91		0.91
5					.90		.90
6					.71		.71
7					.50		.50
8					.58		.58
9					.54		.54
10					.49		.49
11					.45		.45
12					.58		.58
13					.50		.50
14					.63		.63
15					.53		.53
16					.48		.48
17					.46		.46
18					.44		.44
19					.45		.45
20					.45		.45
21					.45		.45
22					.43		.43
23					.42		.42
24					.42		.42
25					.42		.42
26					.42		.42
27					.43		.43
28					.42		.42
29					.44		.44
30					.46		.46
31					.46		.46

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> Yes / No All daily turbidity readings ≤ 5 NTU? Yes / No	CT's met everyday? (see back) Yes / No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? (Yes / No)
Notes:	PRINTED NAME: William Tarr	DATE: 1/31/22
	SIGNATURE: <i>W Tarr</i>	CERT #: Josephine
	PHONE #: (541) 1471-7004	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

GALICE SUBDIVISION WATER CO ID #: OR4101424 WTP-: WTP-A Month/Year:

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
JAN,	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/5pm	2.10	unknown	unknown	10.4 <sup>c</sup>	7.9	186	Yes	unknown
2/5pm	2.00			10.4	7.8	182		
3/6pm	.40			10.4	7.8	149		
4/5pm	.00			10.4	7.8	149		
5/5pm	.01			10.8	7.7	149		
6/5pm	2.20			9.5	7.6	186		
7/4pm	1.80			10.1	7.7	179		
8/5pm	0.94			10.2	7.7	162		
9/5pm	0.28			9.9	7.6	149		
10/8pm	0.53			10.0	7.4	153		
11/4pm	2.20			10.4	7.6	186		
12/5pm	1.13			10.6	7.6	166		
13/6pm	1.13			10.4	7.5	162		
14/5pm	2.20			11.1	7.6	186		
15/5pm	1.79			11.4	7.5	179		
16/6pm	1.02			10.5	7.6	166		
17/5pm	1.01			10.3	7.5	162		
18/4pm	2.00			9.6	7.8	182		
19/5pm	1.21			9.6	7.6	170		
20/4pm	1.82			10.5	7.4	150		
21/3pm	1.51			10.9	7.5	174		
22/5pm	1.58			10.9	7.6	174		
23/5pm	1.48			9.5	7.7	174		
24/8pm	1.36			9.4	7.7	166		
25/8pm	1.06			9.6	7.6	162		
26/5pm	0.98			9.1	7.6	162		
27/5pm	0.91			8.2	7.7	162		
28/5pm	0.73			7.6	7.7	158		
29/5pm	0.40			8.2	7.7	149		
30/5pm	1.09			9.6	7.6	162		
31/5pm	1.15			9.8	7.6	162		

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.

Download form at: [www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-all-unfiltered.pdf](http://www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-all-unfiltered.pdf)