

**OHA - Drinking Water Program – Turbidity Monitoring Report Form** County: **Josephine**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: **GALICE SUBDIVISION WATER CO** ID #: **OR4101424** WTP-: **WTP-A** Month/Year: **Feb, 2022**

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day (NTU)
1					0.44		0.44
2					0.43		0.43
3					0.44		0.44
4					0.44		0.44
5					0.43		0.43
6					0.42		0.42
7					0.43		0.43
8					0.41		0.41
9					0.44		0.44
10					0.43		0.43
11					0.44		0.44
12					0.43		0.43
13					0.43		0.43
14					0.44		0.44
15					0.43		0.43
16					0.44		0.44
17					0.44		0.44
18					0.43		0.43
19					0.43		0.43
20					0.42		0.42
21					0.44		0.44
22					0.45		0.45
23					0.53		0.53
24					0.52		0.52
25					0.50		0.50
26					0.48		0.48
27					0.47		0.47
28					0.48		0.48
29							
30							
31							

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>  95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> Yes / No All daily turbidity readings ≤ 5 NTU? Yes / No	<b>Monthly Summary (Answer Yes or No)</b>	
	CT's met everyday? (see back) Yes / No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? Yes / No
<b>Notes:</b>	PRINTED NAME: <i>William C. Taylor</i>	
	SIGNATURE: <i>[Signature]</i>	DATE: <i>3/1/22</i>
	PHONE #: <i>541 1421-7004</i>	CERT #: <i>Josephine</i>

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

GALICE SUBDIVISION WATER CO ID #: OR4101424 WTP-: WTP-A Month/Year: February 2022

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow				
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]				
1/5pm	1.10	unknown	Unknown	10 °C	7.4	166	Yes	unknown				
2/5pm	1.07	}	}	9.7 °C	7.6	221	}	}				
3/4pm	0.97			9.6 °C	7.4	216						
4/5pm	0.94			8.8 °C	7.7	216						
5/5pm	0.76			9.5 °C	7.6	210						
6/1	0.75			9.7 °C	7.4	210						
7/1	1.05			9.7 °C	7.4	221						
8/1	1.15			9.7 °C	7.5	221						
9/1	1.05			9.8 °C	7.6	221						
10/1	1.25			9.7 °C	7.5	227						
11/1	1.37			10.5 °C	7.5	170						
12/1	0.91			9.7 °C	7.5	216						
13/1	0.54			10.5 °C	7.5	153						
14/6pm	0.42			10.6 °C	7.4	153						
15/6pm	2.20			12.2 °C	7.5	186						
16/6pm	1.14			12.4 °C	7.5	166						
17/6pm	1.15			11.2 °C	7.6	166						
18/7pm	0.88			11.3 °C	7.6	135						
19/6pm	1.00			13.0 °C	7.4	162						
20/5pm	1.32			11.1 °C	7.5	166						
21/6pm	1.14			10.5 °C	7.6	166						
22/6pm	1.50			9.9 °C	7.5	232						
23/5pm	0.94			11.6 °C	7.5	162						
24/5pm	0.64			10.2 °C	7.5	158						
25/6pm	0.42			10.0 °C	7.5	153						
26/6pm	0.32			9.5 °C	7.7	188						
27/5pm	2.00			9.5 °C	7.6	213						
28/6pm	0.64			9.6 °C	7.4	210						
29/												
30/												
31/												

<sup>3</sup>If Cl<sub>2</sub> at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.