

**OHA - Drinking Water Program - Turbidity Monitoring Report Form** County: Josephine  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: GALICE SUBDIVISION WATER CO ID #: OR4101424 WTP:- WTP-A Month/Year: March/2022

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day (NTU)
1					0.46		0.46
2					0.46		0.46
3					0.45		0.45
4					0.48		0.48
5					0.47		0.47
6					0.48		0.48
7					0.47		0.47
8					0.51		0.51
9					0.57		0.57
10					0.48		0.48
11					0.43		0.43
12					0.41		0.41
13					0.42		0.42
14					0.42		0.42
15					0.42		0.42
16					0.42		0.42
17					0.44		0.44
18					0.49		0.49
19					0.46		0.46
20					0.47		0.47
21					0.53		0.53
22					0.49		0.49
23					0.50		0.50
24					0.50		0.50
25					0.53		0.53
26					0.50		0.50
27					0.46		0.46
28					0.45		0.45
29					0.44		0.44
30					0.44		0.44
31					0.44		0.44

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings $\leq$ 1 NTU? <sup>2</sup> Yes / No	All daily turbidity readings $\leq$ 5 NTU? Yes / No	CT's met everyday? (see back) Yes / No	All Cl <sub>2</sub> residual at entry point $\geq$ 0.2 mg/l? Yes / No
Notes:		PRINTED NAME: <u>William C. Tarr</u>	DATE: <u>4/1/2022</u>
		SIGNATURE: <u>W. C. Tarr</u>	CERT #: <u>Josephine</u>
		PHONE #: <u>(541) 471-7004</u>	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

March

OHA - Drinking Water Program - Surface Water Quality Data Form

GALICE SUBDIVISION WATER CO ID #: OR4101424 WTP.: WTP-A Month/Year: 3/2022

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
114pm	0.75	unknown	Unknown	10.1	7.4	131	Yes	Coming
215pm	0.86	Coming	Coming	10.4	7.5	134		
316pm	0.66			10.1	7.6	158		
414pm	0.85			10.1	7.6	162		
516pm	0.64			10.0	7.5	131		
616pm	0.46			10.0	7.5	128		
715pm	0.10			10.0	7.9	149		
816pm	0.05			10.7	7.9	145		
916pm	1.68			10.5	7.5	147		
1016pm	1.40			10.0	7.4	140		
1116pm	1.30			10.0	7.4	140		
1215pm	2.09			10.0	7.5	137		
1315pm	1.09			10.1	7.4	137		
1415pm	0.46			10.8	7.4	144		
1515pm	1.60			10.5	7.5	134		
1615pm	0.90			10.5	7.6	162		
1715pm	0.85			10.5	7.6	162		
1816pm	0.68			10.0	7.5	131		
1915pm	1.02			10.2	7.5	147		
2015pm	0.77			10.2	7.6	158		
2115pm	0.65			10.6	7.6	158		
2215pm	0.60			11.2	7.6	158		
2315pm	0.50			11.8	7.5	153		
2415pm	0.31			12.0	7.5	149		
2516pm	0.48			11.3	7.6	153		
2617pm	1.20			11.4	7.5	157		
2716pm	0.57			11.4	7.5	153		
2816pm	0.94			11.0	7.6	162		
2916pm	0.68			11.0	7.6	158		
3015pm	0.64			11.2	7.6	158		
3115pm	0.80			11.0	7.6	158		

<sup>3</sup>If Cl<sub>2</sub> at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.