

Oregon DHS - Drinking Water Program - Turbidity Monitoring Report Form

System Name: Galice Subdivision

ID #: 41-01424

Month/Year: June 2022

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading (NTU)	Peak Hourly Flow (GPM)
1							4.7	UNKN
2							4.7	
3							4.7	
4							5.2	
5							5.4	
6							5.4	
7							5.6	
8							5.5	
9							5.4	
10							5.2	
11							5.2	
12							4.6	
13							4.2	
14							4.5	
15							4.6	
16							4.6	
17							4.6	
18							4.6	
19							4.5	
20							4.5	
21							4.8	
22							4.7	
23							4.8	
24							5.2	
25							5.1	
26							5.0	
27							5.6	
28							5.0	
29							4.8	
30							4.0	
31								

Conventional or Direct Filtration 95% of turbidity readings ≤ 0.3 NTU? Yes / No All turbidity readings < 1 NTU? Yes / No All turbidity readings < IFE triggers? Yes / No ¹		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) Yes / No All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes / No Cl ₂ residual measured in 95% of distribution samples? Yes / No		
- OR -		PRINTED NAME: <i>William C. Tarr PC</i>		
Slow Sand/Cartridge/Membrane/DE Filtration 95% of turbidity readings ≤ 1 NTU? Yes / No All turbidity readings < 5 NTU? Yes / No		SIGNATURE: <i>William C. Tarr PC</i>		DATE: <i>7/5/22</i>
		PHONE #: (541) <i>471-7004</i>		CERT #: <i>Exophine</i>

¹ IFE = Individual Filter Effluent

Oregon DHS - Drinking Water Program - Surface Water Quality Data Form

System Name: Galice Subdivision

ID #: 41 01424

Month/Year: June 2022

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ppm or mg/L	Contact Time (T) minutes	Actual CT CXT	Temp °C	pH	Required-CT Use tables	CT Met? Yes / No
11/4pm	1.0	unknown	unknown	13.0	7.6	158	Yes
21/4pm	0.8			13.0	7.6	158	
31/4pm	0.7			13.0	7.6	158	
41/5pm	0.7			13.2	7.5	158	
51/5pm	0.4			13.1	7.6	158	
61/5pm	0.2			13.1	7.6	149	
71/4pm	2.0			13.2	7.6	182	
81/4pm	1.70			13.2	7.7	179	
91/5pm	0.88			13.6	7.7	162	
101/6pm	0.3			13.5	7.6	149	
111/4pm	0.3			13.2	7.6	149	
121/5pm	0.8			13.7	7.7	158	
131/5pm	0.9			13.5	7.7	158	
141/6pm	0.8			13.5	7.7	158	
151/5pm	0.70			13.9	7.7	158	
161/6pm	0.60			13.9	7.6	153	
171/6pm	0.40			13.8	7.6	149	
181/6pm	0.18			14.0	7.7	149	
191/7pm	0.14			14.1	7.7	149	
201/4pm	0.07			14.5	7.8	149	
211/4pm	1.50			14.5	7.6	174	
221/5pm	0.90			14.2	7.6	162	
231/5pm	0.80			14.5	7.6	158	
241/7pm	0.87			14.2	7.7	162	
251/7pm	0.80			14.5	7.7	162	
261/6pm	0.76			14.5	7.7	162	
271/4pm	0.7			14.5	7.7	162	
281/4pm	0.72			15.0	7.7	162	
291/4pm	0.6			15.2	7.7	153	
301/5pm	0.54			15.6	7.7	153	
31/							