

OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Josephine Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: GALICE SUBDIVISION WATER CO ID #: OR4101424 WTP-: WTP-A Month/Year:

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1					0.42		0.42
2					0.40		0.40
3					0.43		0.43
4					0.40		0.40
5					0.41		0.41
6					0.42		0.42
7					0.41		0.41
8					0.42		0.42
9					0.42		0.44
10					0.44		0.44
11					0.43		0.43
12					0.44		0.44
13					0.44		0.44
14					0.44		0.44
15					0.44		0.44
16					0.45		0.45
17					0.41		0.41
18					0.45		0.45
19					0.44		0.44
20					0.41		0.41
21					0.42		0.42
22					0.44		0.44
23					0.44		0.44
24					0.44		0.44
25					0.44		0.44
26					0.41		0.41
27					0.44		0.44
28					0.44		0.44
29					0.43		0.43
30					0.41		0.41
31					0.44		0.44

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes / No All daily turbidity readings ≤ 5 NTU? Yes / No	CT's met everyday? (see back) Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes / No
Notes:	PRINTED NAME: <i>William E. Carr DC</i>	DATE: <i>8/10/22</i>
	SIGNATURE: <i>William E. Carr</i>	CERT #: <i>Josephine</i>
	PHONE #: <i>(541) 471-7007</i>	

Including continuous turbidity data; if applicable, for optimization/recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program – Surface Water Quality Data Form

GALICE SUBDIVISION WATER CO ID #: OR4101424 WTP.: WTP-A Month/Year:

July 22

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
11/4 ²⁰	1.0			17.3	7.6	108		
2/5 ⁰⁰	0.7			17.2	7.5	105		
3/5 ⁴⁵	0.08			17.3	7.5	99		
4/4 ³⁰	0.3			17.5	7.6	99		
5/4 ⁴⁵	0.3			17.5	7.5	99		
6/4 ³⁰	0.5			17.5	7.2	99		
7/4 ³⁰	.11			17.5	7.11	99		
8/4 ⁴⁵	1.00			17.0	7.10	108		
9/5 ²⁵	1.12			15.0	7.9	111		
10/5 ³⁰	1.95			17.4	7.4	122		
11/5 ⁴⁵	.95			17.9	7.5	108		
12/5 ³⁰	.76			17.8	7.4	105		
13/4 ⁴⁵	1.02			17.9	7.4	111		
14/3 ⁰⁰	.95			18.4	7.5	108		
15/5 ¹⁵	0.07			18.0	7.6	99		
16/5 ³⁰	.12			17.9	7.3	99		
17/5 ²⁰	1.02			18.1	7.5	111		
18/5 ⁴⁵	.95			17.8	7.4	108		
19/5 ⁴⁵	.75			16.5	7.6	105		
20/5 ³⁰	.90			17.8	7.5	99		
21/5 ⁰⁰	1.02			17.8	7.7	111		
22/4 ³⁰	.75			16.7	7.6	105		
23/4 ³⁰	.94			16.7	7.6	108		
24/4 ⁴⁵	.22			18.0	7.6	99		
25/5 ⁰⁰	.75			18.0	7.7	105		
26/5 ¹⁵	.60			17.9	7.4	105		
27/5 ³⁰	0.07			17.6	7.0	99		
28/5 ⁰⁰	1.02			17.9	7.5	111		
29/4 ⁴⁵	.95			18.0	7.7	108		
30/4 ⁴⁵	.50			16.8	7.8	102		
31/5 ⁰⁰	.15			14.8	7.8	99		

³If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.