

OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Josephine  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: GALICE SUBDIVISION WATER CO ID #: OR4101424 WTP-: WTP-A Month/Year: Feb 2023

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1					.47		.47
2					.46		.46
3					.48		.48
4					.49		.49
5					.48		.48
6					.48		.48
7					.47		.47
8					.47		.47
9					.46		.46
10					.44		.44
11					.44		.44
12					.46		.46
13					.43		.43
14					.50		.50
15					.49		.49
16					.45		.45
17					.48		.48
18					.46		.46
19					.46		.46
20					.46		.46
21					.44		.44
22					.53		.53
23					.48		.48
24					.44		.44
25					.43		.43
26					.44		.44
27					.44		.44
28					.44		.44
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> Yes/No All daily turbidity readings ≤ 5 NTU? Yes/No	Monthly Summary (Answer Yes or No)	
	CT's met everyday? (see back) Yes/No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? Yes/No
Notes:	PRINTED NAME: Janet Arr	DATE: 4/8/2023
	SIGNATURE: <i>Janet Arr</i>	CERT #:
	PHONE #: (541) 471-7004	CERT #:

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

Done Feb - 2023

OHA - Drinking Water Program - Surface Water Quality Data Form

GALICE SUBDIVISION WATER CO ID #: OR4101424 WTP: WTP-A Month/Year:

Feb 2023

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1/ 5:00	.56			9.8	7.5	166	yes	unknown
2/ 5:00	.57			9.9	7.5	166		
3/ 5:00	.54			10.1	7.6	128		
4/ 11	.52			10.0	7.8	153		
5/ 11	.49			9.8	7.6	125		
6/ 11	.42			9.9	7.6	125		
7/ 11	.41			<del>10.8</del>	7.5	125		
8/ 11	1.53			9.9	7.5	140		
9/ 11	1.50			9.8	7.6	187		
10/ 11	1.48			9.9	7.3	187		
11/ 11	1.45			10.2	7.4	140		
12/ 11	1.38			10.2	7.6	140		
13/ 11	1.16			9.8	7.4	187		
14/ 11	.56			10.1	7.6	128		
15/ 11	.38			10.2	7.5	125		
16/ 11	1.16			9.8	7.5	183		
17/ 11	1.40			9.7	7.4	187		
18/ 11	.38			9.7	7.4	166		
19/ 11	.33			<del>10.7</del>	7.5	125		
20/ 11	1.04			<del>10.7</del>	7.5	134		
21/ 11	.47			<del>10.8</del>	7.7	12.8		
22/ 11	.68			<del>10.8</del>	7.3	128		
23/ 11	.57			<del>10.9</del>	7.3	128		
24/ 11	.44			9.7	7.5	125		
25/ 11	.16			9.7	7.4	166		
26/ 11	1.38			9.6	7.4	187		
27/ 11	.48			9.5	7.5	166		
28/ 11	.75			9.5	7.6	171		
29/ 11								
30/ 11								
31/ 11								

<sup>3</sup>If Cl<sub>2</sub> at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.  
 Download form at: [www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/lurb-all-unfiltered.pdf](http://www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/lurb-all-unfiltered.pdf)