

OHA - Drinking Water Program - Turbidity Monitoring Report Form **County: Josephine**
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: GALICE SUBDIVISION WATER CO ID #: OR4101424 WTP-: WTP-A Month/Year: December 23

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1					.46		.46
2					.45		.45
3					.44		.44
4					.48		.48
5					.44		.44
6					.46		.46
7					.48		.48
8					.44		.44
9					.44		.44
10					.44		.44
11					.45		.45
12					.47		.47
13					.46		.46
14					.46		.46
15					.46		.46
16					.45		.45
17					.44		.44
18					.44		.44
19					.47		.47
20					.48		.48
21					.47		.47
22					.47		.47
23					.47		.47
24					.46		.46
25					.46		.46
26					.46		.46
27					.44		.44
28					.48		.48
29					.48		.48
30					.46		.46
31					.45		.45

Slow Sand/Membrane/DE Filtration/Unfiltered
 5% of daily turbidity readings ≤ 1 NTU? ² Yes / No
 All daily turbidity readings ≤ 5 NTU? Yes / No

Monthly Summary (Answer Yes or No)
 CT's met everyday? (see back) Yes / No
 All Cl₂ residual at entry point ≥ 0.2 mg/l? Yes / No

Notes:

PRINTED NAME: Janet Tarr
 SIGNATURE: [Signature] DATE: 1/16/2024
 PHONE #: 541 1471 7004 CERT #:

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM"

OHA - Drinking Water Program - Surface Water Quality Data Form

GALICE SUBDIVISION WATER CO ID #: OR4101424 WTP.: WTP-A Month/Year: December 2023

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1/50	.50			10.5	7.6	125		
2/50	.38			10.8	7.7	125		
3/50	.25			10.8	7.6	125		
4/50	.15			10.5	7.6	125		
5/50	.04			10.8	7.5	125		
6/50	.72			10.8	7.5	128		
7/50	.25			10.6	7.5	125		
8/50	.00			10.4	7.6	125		
9/50	1.35			10.6	7.6	137		
10/50	1.26			10.5	7.6	137		
11/50	.78			10.4	7.6	128		
12/50	.35			10.0	7.7	125		
13/50	.15			10.2	7.5	125		
14/50	.98			10.0	7.6	134		
15/50	.75			10.1	7.7	128		
16/50	.46			10.1	7.6	125		
17/50	.38			9.8	7.6	125		
18/50	.25			9.6	7.7	125		
19/50	.08			9.5	7.7	125		
20/50	1.05			9.6	7.6	134		
21/50	.88			9.3	7.6	131		
22/50	.65			9.4	7.6	128		
23/50	.42			8.9	7.5	125		
24/50	.38			9.0	7.5	125		
25/50	.22			9.2	7.6	125		
26/50	.15			9.3	7.7	125		
27/50	.96			9.4	7.4	134		
28/50	.87			9.5	7.6	131		
29/50	.17			10.5	7.6	125		
30/50	.16			11.5	7.6	125		
31/50	1.10			10.8	7.6	134		

³If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.
 Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/lurb-all-unfiltered.pdf