

OHA - Drinking Water Services - Surface Water Quality Data Form

County:

Coos

Cartridge or Bag Filtration

Month/Year:

May-22



System Name:		Country Club Estates		ID#:	41 01501	WTP ID:	TP-	B
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]		
1	16.00	16.00	0.00	15.00	0.32			
2	16.00	16.00	0.00	15.00	0.32			
3	16.00	16.00	0.00	15.00	0.27			
4	16.00	16.00	0.00	15.00	0.43			
5	16.00	16.00	0.00	15.00	0.28			
6	16.00	16.00	0.00	15.00	0.30			
7	16.00	16.00	0.00	15.00	0.29			
8	16.00	16.00	0.00	15.00	0.42			
9	16.00	16.00	0.00	15.00	0.28			
10	16.00	16.00	0.00	15.00	0.55			
11	16.00	16.00	0.00	15.00	0.36			
12	16.00	16.00	0.00	15.00	0.69			
13	16.00	16.00	0.00	15.00	0.25			
14	16.00	16.00	0.00	15.00	0.55			
15	16.00	16.00	0.00	15.00	0.56			
16	16.00	16.00	0.00	15.00	0.50			
17	16.00	16.00	0.00	15.00	0.53			
18	16.00	16.00	0.00	15.00	0.58			
19	16.00	16.00	0.00	15.00	0.54			
20	16.00	16.00	0.00	15.00	0.31			
21	16.00	16.00	0.00	15.00	0.29			
22	16.00	16.00	0.00	15.00	0.53			
23	16.00	16.00	0.00	15.00	0.55			
24	16.00	16.00	0.00	15.00	0.28			
25	16.00	16.00	0.00	15.00	0.38			
26	16.00	16.00	0.00	15.00	0.33			
27	16.00	16.00	0.00	15.00	0.39			
28	16.00	16.00	0.00	15.00	0.37			
29	16.00	16.00	0.00	15.00	0.34			
30	16.00	16.00	0.00	15.00	0.34			
31	16.00	16.00	0.00	15.00	0.39			
Cartridge & Bag Filtration					Monthly Summary (Answer Yes or No)			
95% of daily turbidity readings ≤ 1 NTU? YES					CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?		
All daily turbidity readings ≤ 5 NTU? YES					YES	YES		
Notes: PSI = pounds per square inch					PRINTED NAME: Mark Merry			
PSID = pounds per square inch difference (before filter - after filter)					SIGNATURE: Electronic Submittal			
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.					7/2/2022			
					PHONE #: (503) 812-7320			
					CERT #:T-5204			

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not

correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : B

System Name: Country Club Estates

ID#: 41 01501

Month/Year: May-22

Disinfection
Giardia Log
Inactiv:

1

Date / Time	Minimum Cl ₂ Residual before or at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.4	340	136.0	15.2	7.00	25.1	YES	7.5
2	0.4	340	136.0	15.2	7.10	26.0	YES	7.5
3	0.2	340	68.0	15.6	7.10	24.8	YES	7.5
4	0.2	340	68.0	15.9	7.00	23.4	YES	7.5
5	0.4	340	136.0	15.9	7.00	23.9	YES	7.5
6	0.6	340	204.0	15.9	6.90	23.6	YES	7.5
7	0.6	340	204.0	16.0	6.90	23.4	YES	7.5
8	0.6	340	204.0	15.9	7.10	25.4	YES	7.5
9	0.6	340	204.0	16.2	7.20	25.9	YES	7.5
10	0.4	340	136.0	16.5	7.00	23.0	YES	7.5
11	0.3	340	102.0	16.9	7.00	22.1	YES	7.5
12	0.4	340	136.0	16.1	7.00	23.6	YES	7.5
13	0.4	340	136.0	15.8	7.00	24.1	YES	7.5
14	0.5	340	170.0	15.6	7.00	24.7	YES	7.5
15	0.4	340	136.0	15.7	7.00	24.3	YES	7.5
16	0.4	340	136.0	15.7	7.00	24.3	YES	7.5
17	0.6	340	204.0	16.0	7.10	25.3	YES	7.5
18	0.6	340	204.0	16.1	7.10	25.1	YES	7.5
19	0.6	340	204.0	16.5	7.10	24.4	YES	7.5
20	0.6	340	204.0	15.9	7.10	25.4	YES	7.5
21	0.6	340	204.0	16.6	7.20	25.2	YES	7.5
22	0.4	340	136.0	17.0	7.20	24.0	YES	7.5
23	0.4	340	136.0	16.4	7.20	24.9	YES	7.5
24	0.4	340	136.0	16.9	7.10	23.2	YES	7.5
25	0.4	340	136.0	17.2	7.10	22.8	YES	7.5
26	0.4	340	136.0	18.2	7.00	20.5	YES	7.5
27	0.4	340	136.0	18.2	7.00	20.5	YES	7.5
28	0.2	340	68.0	18.4	7.00	19.8	YES	7.5
29	0.4	340	136.0	18.3	7.00	20.4	YES	7.5
30	0.4	340	136.0	18.5	6.70	17.9	YES	7.5
31	0.4	340	136.0	18.5	6.70	17.9	YES	7.5

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dnce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350