

OHA - Drinking Water Services - Surface Water Quality Data Form						County:	Coos
Cartridge or Bag Filtration						Month/Year:	Jul-22
System Name:	Country Club Estates WD			PWS ID#: 41-01501		WTP ID: TP FOR CBNB	
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]	
1	30.00	28.00	2.00	15.00	0.34		
2	28.00	28.00	0.00	15.00	0.33		
3	30.00	30.00	0.00	15.00	0.37		
4	31.00	31.00	0.00	15.00	0.32		
5	30.00	30.00	0.00	15.00	0.33		
6	30.00	30.00	0.00	15.00	0.34		
7	30.00	30.00	0.00	15.00	0.31		
8	30.00	30.00	0.00	15.00	0.34		
9	30.00	30.00	0.00	15.00	0.39		
10	30.00	30.00	0.00	15.00	0.34		
11	30.00	30.00	0.00	15.00	0.40		
12	30.00	30.00	0.00	15.00	0.39		
13	30.00	30.00	0.00	15.00	0.69		
14	30.00	30.00	0.00	15.00	0.33		
15	30.00	30.00	0.00	15.00	0.30		
16	30.00	30.00	0.00	15.00	0.27		
17	30.00	30.00	0.00	15.00	0.56		
18	30.00	30.00	0.00	15.00	0.62		
19	30.00	30.00	0.00	15.00	0.49		
20	30.00	30.00	0.00	15.00	0.45		
21	30.00	30.00	0.00	15.00	0.38		
22	30.00	30.00	0.00	15.00	0.29		
23	30.00	30.00	0.00	15.00	0.37		
24	30.00	30.00	0.00	15.00	0.47		
25	30.00	30.00	0.00	15.00	0.36		
26	30.00	30.00	0.00	15.00	0.24		
27	30.00	30.00	0.00	15.00	0.28		
28	30.00	30.00	0.00	15.00	0.27		
29	30.00	30.00	0.00	15.00	0.29		
30	30.00	30.00	0.00	15.00	0.33		
31	30.00	30.00	0.00	15.00	0.47		
Cartridge & Bag Filtration					Monthly Summary UV Summary (Circle Yes or No)		
95% of daily turbidity readings ≤ 1 NTU?				Yes	Is any off -spec water produced in the month		
All daily turbidity readings ≤ 5 NTU?				Yes	☐	Yes	No ☐ No ☐
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.					PRINTED NAME:		Mark Merry
					SIGNATURE: Mark Merry		DATE: 09-01-2022
					PHONE #: 503-812-7320		CERT #: T-5204

¹ Including continuous NTU data, if applicable, for optimization recording purposes.

Oregon DHS - Drinking Water Services – Surface Water Quality Data

System Name:	Country Club Estates WD	ID# 41 01501	Month/Year: Aug / 2022
Minimum Validated UVT : 75%		Duty sensor variation from reference sensor %: _____	

Date	Peak Hourly Demand Flow	Minimum Dose	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm/unit]	[^{mJ} /cm ²]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	10	457	y	9446	0	0%
2	10	459	y	9288	0	0%
3	10	445	y	6840	0	0%
4	10	454	y	9777	0	0%
5	10	447	y	9878	0	0%
6	11	409	y	13000	0	0%
7	11	407	y	4010	0	0%
8	10	453	y	8880	0	0%
9	10	454	y	6960	0	0%
10	10	431	y	7001	0	0%
11	10	421	y	9288	0	0%
12	10	430	y	9092	0	0%
13	10	505	y	9030	0	0%
14	10	405	y	5040	0	0%
15	10	409	y	6938	0	0%
16	10	389	y	7700	0	0%
17	8	418	y	9670	0	0%
18	10	372	y	2700	0	0%
19	10	378	y	7870	0	0%
20	9.5	397	y	6920	0	0%
21	10	408	y	6660	0	0%
22	10.5	350	y	8160	0	0%
23	9.5	370	y	6470	0	0%
24	9	370	y	7390	0	0%
25	10	380	y	6310	0	0%
26	10	410	y	3160	0	0%
27	10	340	y	5320	0	0%
28	10	328	y	6930	0	0%
29	10.5	318	y	6490	0	0%
30	10.5	310	y	5930	0	0%
31	10	320	y	6070	0	0%
Monthly Totals				228,218		%

rev 1/11 I:\MC\forms\Turbidity Report Form – UV and opt mod.doc

Signature: _____ Mark Merry Op Cert #: _____ Date: _____ 9/1/2022