

OHA - Drinking Water Services - Surface Water Quality Data Form						County:	Coos
Cartridge or Bag Filtration						Month/Year:	Jul-25
System Name:	Country Club Estates WD			PWS ID#: 41-01501		WTP ID: TP FOR CBNB	
Day	41	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]	
1	31.00	28.00	3.00	15.00	0.13		
2	30.00	27.00	3.00	15.00	0.12		
3	30.00	28.00	2.00	15.00	0.11		
4	30.00	27.00	3.00	15.00	0.13		
5	42.00	40.00	2.00	15.00	0.14		
6	44.00	43.00	1.00	15.00	0.14		
7	36.00	33.00	3.00	15.00	0.24		
8	41.00	39.00	2.00	15.00	0.10		
9	30.00	28.00	2.00	15.00	0.09		
10	29.00	26.00	3.00	15.00	14.00		
11	30.00	28.00	2.00	15.00	0.14		
12	28.00	26.00	2.00	15.00	0.24		
13	30.00	27.00	3.00	15.00	0.16		
14	31.00	28.00	3.00	15.00	0.16		
15	31.00	28.00	3.00	15.00	0.14		
16	31.00	28.00	3.00	15.00	0.14		
17	29.00	26.00	3.00	15.00	0.17		
18	29.00	26.00	3.00	15.00	0.14		
19	31.00	28.00	3.00	15.00	0.29		
20	31.00	28.00	3.00	15.00	0.26		
21	30.00	27.00	3.00	15.00	0.21		
22	30.00	28.00	2.00	15.00	0.23		
23	30.00	28.00	2.00	15.00	0.12		
24	31.00	28.00	3.00	15.00	0.13		
25	31.00	28.00	3.00	15.00	0.16		
26	30.00	27.00	3.00	15.00	0.19		
27	31.00	29.00	2.00	15.00	0.15		
28	34.00	30.00	4.00	15.00	0.18		
29	37.00	32.00	5.00	15.00	0.16		
30	40.00	35.00	5.00	15.00	0.20		
31	42.00	36	6.00	15.00	0.20		
Cartridge & Bag Filtration					Monthly Summary UV Summary (Circle Yes or No)		
95% of daily turbidity readings ≤ 1 NTU?				Yes	Is any off -spec water produced in the month		
All daily turbidity readings ≤ 5 NTU?				Yes	No		
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.					PRINTED NAME:		Mark Merry
					SIGNATURE: Electronic		DATE: 08/03/2025
					PHONE #: 503-812-7320		CERT #: T-5204

¹ Including continuous NTU data, if applicable, for optimization recording purposes.

Oregon DHS - Drinking Water Services – Surface Water Quality Data

System Name:	Country Club Estates WD	ID# 41 01501	Month/Year: Jul / 2025
Minimum Validated UVT : 75%		Duty sensor variation from reference sensor %: 1.0 % 0%	

Date	Peak Hourly Demand Flow	Minimum Dose	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm/unit]	[^{mJ} /cm ²]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	11.5	443	y	7304	0	0%
2	11.5	442	y	7086	0	0%
3	11	439	y	6777	0	0%
4	11	430454	y	7020	0	0%
5	10.5	417	y	6969	0	0%
6	11.5	412	y	7819	0	0%
7	11.5	415	y	9830	0	0%
8	11.5	397	y	7920	0	0%
9	11.5	388	y	7620	0	0%
10	12	396	y	11190	0	0%
11	11.5	380	y	8360	0	0%
12	10.5	380	y	7165	0	0%
13	10.5	372	y	7152	0	0%
14	11.5	361	y	9074	0	0%
15	11.5	362	y	7367	0	0%
16	11.5	353	y	10204	0	0%
17	11	339	y	10979	0	0%
18	11	354	y	8904	0	0%
19	11	352	y	5773	0	0%
20	11.5	355	y	7896	0	0%
21	11	344	y	8750	0	0%
22	11	329	y	5740	0	0%
23	11	344	y	7614	0	0%
24	11.5	329	y	7049	0	0%
25	11.5	325	y	7622	0	0%
26	11.5	315	y	6987	0	0%
27	11.5	316	y	6267	0	0%
28	10.5	340	y	7670	0	0%
29	12	309	y	5353	0	0%
30	11.5	308	y	9868	0	0%
31	12	299	y	7544	0	0%
				242,873		

rev 1/11 I:\MC\forms\Turbidity Report Form – UV and opt mod.doc

Signature: <u>Mark Merry</u>	Op Cert #: <u>T-5204</u>	Date: <u>8/1/2025</u>
------------------------------	--------------------------	-----------------------