


OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

| | |
|-------------|--------|
| County: | Lane |
| Month/Year: | Jul-21 |

| System Name: | Row River Water Dist | | ID#: | 01515 | WTP : TP - | | A |
|---|----------------------|---------------|---------------|---------------|---|--|---|
| Day | 12 AM [NTU] | 4 AM [NTU] | 8 AM [NTU] | NOON [NTU] | 4 PM [NTU] | 8 PM [NTU] | Highest Reading of the day ¹ [NTU] |
| 1 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 2 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 3 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 4 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 5 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 6 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 7 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 8 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 9 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 10 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 11 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 12 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 13 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 14 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 15 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 16 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 17 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 18 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 19 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 20 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 21 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 22 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 23 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 24 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 25 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 26 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 27 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 28 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 29 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 30 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 31 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| Slow Sand/Membrane/DE Filtration/Unfiltered | | | | | Monthly Summary (Answer Yes or No) | | |
| 95% of daily turbidity readings ≤ 1 NTU? ² | | | | | YES | CT's met everyday? (see back) | All Cl ₂ residual at entry point ≥ 0.2 mg/l? |
| All daily turbidity readings ≤ 5 NTU? | | | | | YES | YES | YES |
| Notes: | | | | | James D Eckstine | | |
| | | | | | SIGNATURE: |  | 8/10/21 |
| | | | | | 541-946-1655 | | T-08619 |

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

A

System Name:

Row River Water Dist

ID#: 41

01515

Month/Year: Jul-21

Disinfection Giardia Log

Inactiv:

1.0

| Date / Time | Minimum Cl ₂ Residual at 1st User (C) ³ | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? ³ | Peak Hourly Demand Flow |
|-------------|--|------------------------|-----------|-------|------|-------------|----------------------|----------------------------|
| | [ppm or mg/L] | [minutes] | C X T | [° C] | | formula | Yes / No | [GPM] |
| 1 | 1.19 | 1185 | 1410.2 | 21.0 | 7.30 | 20.8 | YES | 285 |
| 2 | 1.2 | 1185 | 1422.0 | 19.0 | 7.31 | 23.9 | YES | 285 |
| 3 | 1.22 | 1185 | 1445.7 | 19.0 | 7.32 | 24.1 | YES | 285 |
| 4 | 1.29 | 1185 | 1528.7 | 19.0 | 7.33 | 24.3 | YES | 285 |
| 5 | 1.27 | 1185 | 1505.0 | 19.0 | 7.31 | 24.1 | YES | 285 |
| 6 | 1.28 | 1185 | 1516.8 | 19.0 | 7.29 | 24.0 | YES | 285 |
| 7 | 1.26 | 1185 | 1493.1 | 19.0 | 7.31 | 24.1 | YES | 285 |
| 8 | 1.21 | 1185 | 1433.9 | 19.0 | 7.27 | 23.6 | YES | 285 |
| 9 | 1.23 | 1185 | 1457.6 | 19.0 | 7.28 | 23.7 | YES | 285 |
| 10 | 1.19 | 1185 | 1410.2 | 19.0 | 7.29 | 23.7 | YES | 285 |
| 11 | 1.2 | 1185 | 1422.0 | 19.0 | 7.29 | 23.7 | YES | 285 |
| 12 | 1.23 | 1185 | 1457.6 | 20.0 | 7.30 | 22.4 | YES | 285 |
| 13 | 1.21 | 1185 | 1433.9 | 20.0 | 7.27 | 22.1 | YES | 285 |
| 14 | 1.2 | 1185 | 1422.0 | 19.0 | 7.29 | 23.7 | YES | 285 |
| 15 | 1.2 | 1185 | 1422.0 | 18.0 | 7.27 | 25.2 | YES | 285 |
| 16 | 1.21 | 1185 | 1433.9 | 18.0 | 7.28 | 25.3 | YES | 285 |
| 17 | 1.23 | 1185 | 1457.6 | 18.0 | 7.29 | 25.5 | YES | 285 |
| 18 | 1.09 | 1185 | 1291.7 | 19.0 | 7.27 | 23.3 | YES | 285 |
| 19 | 1.15 | 1185 | 1362.8 | 19.0 | 7.29 | 23.6 | YES | 285 |
| 20 | 1.18 | 1185 | 1398.3 | 19.0 | 7.29 | 23.7 | YES | 285 |
| 21 | 1.17 | 1185 | 1386.5 | 19.0 | 7.27 | 23.5 | YES | 285 |
| 22 | 1.27 | 1185 | 1505.0 | 17.0 | 7.27 | 27.2 | YES | 285 |
| 23 | 1.25 | 1185 | 1481.3 | 17.0 | 7.26 | 27.0 | YES | 285 |
| 24 | 1.29 | 1185 | 1528.7 | 17.0 | 7.28 | 27.3 | YES | 285 |
| 25 | 1.28 | 1185 | 1516.8 | 18.0 | 7.27 | 25.4 | YES | 285 |
| 26 | 1.3 | 1185 | 1540.5 | 18.0 | 7.29 | 25.7 | YES | 285 |
| 27 | 1.28 | 1185 | 1516.8 | 19.0 | 7.27 | 23.8 | YES | 285 |
| 28 | 1.29 | 1185 | 1528.7 | 20.0 | 7.28 | 22.3 | YES | 285 |
| 29 | 1.25 | 1185 | 1481.3 | 20.0 | 7.30 | 22.4 | YES | 285 |
| 30 | 1.26 | 1185 | 1493.1 | 20.0 | 7.27 | 22.2 | YES | 285 |
| 31 | 1.23 | 1185 | 1457.6 | 20.0 | 7.29 | 22.3 | YES | 285 |

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013