


OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Lane**
 Month/Year: **Sep-21**
 WTP: **TP - A**

System Name:	Row River Water Dist						ID#: 41	01515
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]	
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
12	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
14	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
31								

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ²	YES	CT's met everyday? (see back)
All daily turbidity readings \leq 5 NTU?	YES	All Cl2 residual at entry point \geq 0.2 mg/l?
		YES
Notes:	James D Eckstine	
	SIGNATURE: 	10/10/21
	541-946-1655	T-08619

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A

System Name: Row River Water Dist ID#: 41 01515 Month/Year: Sep-21

Disinfection Giardia Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.23	1185	1457.6	15.0	7.18	29.9	YES	260
2	1.26	1185	1493.1	15.0	7.26	30.9	YES	260
3	1.25	1185	1481.3	15.0	7.15	29.6	YES	260
4	1.22	1185	1445.7	15.0	7.22	30.3	YES	260
5	1.24	1185	1469.4	15.0	7.24	30.6	YES	260
6	1.33	1185	1576.1	16.0	7.33	29.9	YES	260
7	1.39	1185	1647.2	17.0	7.39	28.8	YES	260
8	1.35	1185	1599.8	17.0	7.22	26.9	YES	260
9	1.25	1185	1481.3	17.0	7.20	26.4	YES	260
10	1.37	1185	1623.5	17.0	7.21	26.9	YES	260
11	1.26	1185	1493.1	17.0	7.21	26.5	YES	260
12	1.24	1185	1469.4	17.0	7.20	26.4	YES	260
13	1.21	1185	1433.9	17.0	7.21	26.4	YES	260
14	1.18	1185	1398.3	12.0	7.23	37.4	YES	260
15	1.23	1185	1457.6	12.0	7.21	37.4	YES	260
16	1.23	1185	1457.6	13.0	7.21	34.5	YES	260
17	1.21	1185	1433.9	14.0	7.21	32.2	YES	260
18	1.19	1185	1410.2	14.0	7.18	31.8	YES	260
19	1.21	1185	1433.9	14.0	7.21	32.2	YES	260
20	1.19	1185	1410.2	13.0	7.22	34.5	YES	260
21	1.15	1185	1362.8	13.0	7.20	34.1	YES	260
22	1.24	1185	1469.4	13.0	7.17	34.1	YES	260
23	1.29	1185	1528.7	12.0	7.18	37.3	YES	260
24	1.34	1185	1587.9	8.0	7.19	48.9	YES	260
25	1.31	1185	1552.4	8.0	7.21	49.1	YES	260
26	1.14	1185	1350.9	8.0	7.21	48.1	YES	260
27	1.12	1185	1327.2	8.0	7.24	48.5	YES	260
28	1.38	1185	1635.3	8.0	7.24	50.0	YES	260
29	1.39	1185	1647.2	8.0	7.25	50.2	YES	260
30	1.31	1185	1552.4	8.0	7.42	52.9	YES	260
31		1185						

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013