

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County:	Lane
Month/Year:	Aug-22

System Name:		Row River Water District		ID#:	41	01515	WTP : TP -	A
Day		12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1		0.03	0.03	0.03	0.03	0.03	0.03	0.03
2		0.03	0.03	0.03	0.03	0.03	0.03	0.03
3		0.03	0.03	0.03	0.03	0.03	0.03	0.03
4		0.03	0.03	0.03	0.03	0.03	0.03	0.03
5		0.03	0.03	0.03	0.03	0.03	0.03	0.03
6		0.03	0.03	0.03	0.03	0.03	0.03	0.03
7		0.03	0.03	0.03	0.03	0.03	0.03	0.03
8		0.03	0.03	0.03	0.03	0.03	0.03	0.03
9		0.03	0.03	0.03	0.03	0.03	0.03	0.03
10		0.03	0.03	0.03	0.03	0.03	0.03	0.03
11		0.03	0.03	0.03	0.03	0.03	0.03	0.03
12		0.03	0.03	0.03	0.03	0.03	0.03	0.03
13		0.03	0.03	0.03	0.03	0.03	0.03	0.03
14		0.03	0.03	0.03	0.03	0.03	0.03	0.03
15		0.03	0.03	0.03	0.03	0.03	0.03	0.03
16		0.03	0.03	0.03	0.03	0.03	0.03	0.03
17		0.03	0.03	0.03	0.03	0.03	0.03	0.03
18		0.03	0.03	0.03	0.03	0.03	0.03	0.03
19		0.03	0.03	0.03	0.03	0.03	0.03	0.03
20		0.03	0.03	0.03	0.03	0.03	0.03	0.03
21		0.03	0.03	0.03	0.03	0.03	0.03	0.03
22		0.03	0.03	0.03	0.03	0.03	0.03	0.03
23		0.03	0.03	0.03	0.03	0.03	0.03	0.03
24		0.03	0.03	0.03	0.03	0.03	0.03	0.03
25		0.03	0.03	0.03	0.03	0.03	0.03	0.03
26		0.03	0.03	0.03	0.03	0.03	0.03	0.03
27		0.03	0.03	0.03	0.03	0.03	0.03	0.03
28		0.03	0.03	0.03	0.03	0.03	0.03	0.03
29		0.03	0.03	0.03	0.03	0.03	0.03	0.03
30		0.03	0.03	0.03	0.03	0.03	0.03	0.03
31		0.03	0.03	0.03	0.03	0.03	0.03	0.03
Slow Sand/Membrane/DE Filtration/Unfiltered					Monthly Summary (Answer Yes or No)			
95% of daily turbidity readings \leq 1 NTU? ²			Yes / No	CT's met everyday? (see back)		All Cl2 residual at entry point \geq 0.2 mg/l?		
All daily turbidity readings \leq 5 NTU?			Yes / No	Yes / No	Yes / No	Yes / No		
Notes:				James Eckstine				
				SIGNATURE: 	9/1/2022			
				541-946-1655	T08619			

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP-:

A

System Name: Row River Water Dis ID#: 41 01515 Month/Year: 22-Aug

Disinfection Giardia Log

Inactiv:

1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/l]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1	1.32	1185	1564.2	20.0	7.29	22.5	Yes	290
2	1.28	1185	1516.8	20.0	7.29	22.4	Yes	290
3	1.25	1185	1481.3	20.0	7.28	22.2	Yes	290
4	1.26	1185	1493.1	20.0	7.27	22.2	Yes	290
5	1.28	1185	1516.8	19.0	7.29	24.0	Yes	290
6	1.26	1185	1493.1	18.0	7.27	25.4	Yes	290
7	1.26	1185	1493.1	20.0	7.26	22.1	Yes	290
8	1.25	1185	1481.3	20.0	7.26	22.1	Yes	290
9	1.24	1185	1469.4	20.0	7.24	21.9	Yes	290
10	1.29	1185	1528.7	20.0	7.26	22.2	Yes	290
11	1.28	1185	1516.8	19.0	7.23	23.4	Yes	290
12	1.3	1185	1540.5	18.0	7.22	25.0	Yes	290
13	1.33	1185	1576.1	18.0	7.24	25.3	Yes	290
14	1.34	1185	1587.9	16.0	7.35	30.2	Yes	290
15	1.36	1185	1611.6	18.0	7.26	25.6	Yes	290
16	1.35	1185	1599.8	18.0	7.28	25.7	Yes	290
17	1.33	1185	1576.1	19.0	7.27	23.9	Yes	300
18	0.31	1185	367.4	19.0	7.26	21.2	Yes	300
19	0.32	1185	379.2	19.0	7.26	21.2	Yes	300
20	0.31	1185	367.4	19.0	7.27	21.3	Yes	300
21	0.33	1185	391.1	19.0	7.28	21.4	Yes	300
22	1.32	1185	1564.2	19.0	7.28	24.0	Yes	300
23	1.34	1185	1587.9	18.0	7.30	25.9	Yes	300
24	1.31	1185	1552.4	18.0	7.27	25.5	Yes	300
25	1.32	1185	1564.2	19.0	7.26	23.8	Yes	300
26	1.33	1185	1576.1	20.0	7.29	22.5	Yes	300
27	1.35	1185	1599.8	19.0	7.27	24.0	Yes	300
28	1.37	1185	1623.5	17.0	7.23	27.1	Yes	300
29	1.35	1185	1599.8	17.0	7.22	26.9	Yes	300
30	1.37	1185	1623.5	17.0	7.24	27.2	Yes	300
31	1.38	1185	1635.3	18.0	7.23	25.3	Yes	300

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350