



## OHA - Drinking Water Services - Surface Water Quality Data Form

Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County:	Lane
Month/Year:	Sep-22

System Name:		Row River Water District		ID#:	41	01515	WTP :	TP -	A	
Day		12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]		
1		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
2		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
3		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
4		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
5		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
6		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
7		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
8		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
9		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
10		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
11		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
12		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
13		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
14		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
15		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
16		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
17		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
18		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
19		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
20		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
21		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
22		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
23		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
24		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
25		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
26		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
27		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
28		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
29		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
30		0.03	0.03	0.03	0.03	0.03	0.03		0.03	
31										
<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>							<b>Monthly Summary (Answer Yes or No)</b>			
95% of daily turbidity readings $\leq$ 1 NTU? <sup>2</sup>				Yes / No	CT's met everyday? (see back)			All Cl2 residual at entry point $\geq$ 0.2 mg/l?		
All daily turbidity readings $\leq$ 5 NTU?				Yes / No	Yes / No			Yes / No		
Notes:							James Eckstine 			
							SIGNATURE: 			
							541-946-1655			
							T08619			

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

## OHA - Drinking Water Services - Surface Water Quality Data Form

WTP -

A

System Name: Row River Water Dis ID#: 41 01515 Month/Year: 22-Sep

Disinfection Giardia Log

Inactiv:

1.0

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.39	1185	1647.2	18.0	7.21	25.2	Yes	290
2	1.37	1185	1623.5	18.0	7.23	25.3	Yes	290
3	1.35	1185	1599.8	18.0	7.22	25.2	Yes	290
4	1.36	1185	1611.6	17.0	7.22	26.9	Yes	290
5	1.39	1185	1647.2	17.0	7.26	27.4	Yes	290
6	1.38	1185	1635.3	18.0	7.25	25.5	Yes	290
7	1.39	1185	1647.2	18.0	7.25	25.6	Yes	290
8	1.38	1185	1635.3	17.0	7.27	27.5	Yes	290
9	1.37	1185	1623.5	17.0	7.24	27.2	Yes	290
10	1.36	1185	1611.6	16.0	7.21	28.7	Yes	290
11	1.34	1185	1587.9	16.0	7.20	28.5	Yes	290
12	1.33	1185	1576.1	16.0	7.20	28.5	Yes	290
13	1.34	1185	1587.9	17.0	7.23	27.0	Yes	290
14	1.36	1185	1611.6	17.0	7.26	27.3	Yes	290
15	1.37	1185	1623.5	16.0	7.22	28.8	Yes	290
16	1.34	1185	1587.9	16.0	7.22	28.7	Yes	290
17	1.34	1185	1587.9	16.0	7.21	28.6	Yes	290
18	1.31	1185	1552.4	15.0	7.23	30.7	Yes	290
19	1.33	1185	1576.1	15.0	7.27	31.3	Yes	290
20	1.3	1185	1540.5	15.0	7.26	31.0	Yes	290
21	1.28	1185	1516.8	15.0	7.24	30.7	Yes	290
22	0.99	1185	1173.2	15.0	7.22	29.5	Yes	290
23	0.91	1185	1078.4	15.0	7.22	29.3	Yes	290
24	1.25	1185	1481.3	15.0	7.21	30.3	Yes	290
25	1.18	1185	1398.3	15.0	7.23	30.3	Yes	290
26	1.31	1185	1552.4	14.0	7.27	33.3	Yes	290
27	1.39	1185	1647.2	14.0	7.26	33.5	Yes	290
28	1.41	1185	1670.9	14.0	7.24	33.4	Yes	290
29	1.4	1185	1659.0	15.0	7.24	31.2	Yes	290
30	1.15	1185	1362.8	15.0	7.23	30.2	Yes	290

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

PAGE 2 of 2