


OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County:	Lane
Month/Year:	23-Jan

System Name:	Row River Valley Water District		ID#:	01515	WTP : TP -		A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03
12	0.03	0.03	0.03	0.03	0.03	0.03	0.03
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03
14	0.03	0.03	0.03	0.03	0.03	0.03	0.03
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03
16	0.03	0.04	0.04	0.04	0.04	0.04	0.04
17	0.04	0.04	0.04	0.04	0.04	0.04	0.04
18	0.04	0.04	0.04	0.04	0.04	0.03	0.04
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03
31	0.03	0.03	0.03	0.03	0.03	0.03	0.03
Slow Sand/Membrane/DE Filtration/Unfiltered					Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings \leq 1 NTU? ²		Yes / No		CT's met everyday? (see back)		All Cl ₂ residual at entry point \geq 0.2 mg/l?	
All daily turbidity readings \leq 5 NTU?		Yes / No		Yes / No		Yes / No	
Notes:					James D Eckstine		
					SIGNATURE: 		
					541-946-1655		

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP-:

A

System Name: Row River Valley Water Dis ID#: 41 01515 Month/Year: 23-Jan

Disinfection Giardia Log

Inactiv:

1.0

	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/l]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1	1.5	1185	1777.5	8.0	7.17	49.4	YES	300
2	1.47	1185	1742.0	8.0	7.16	49.1	YES	300
3	1.499	1185	1776.3	7.0	7.15	52.5	YES	300
4	1.51	1185	1789.4	7.0	7.17	52.9	YES	300
5	1.48	1185	1753.8	7.0	7.16	52.6	YES	300
6	1.55	1185	1836.8	7.0	7.20	53.8	YES	300
7	1.41	1185	1670.9	7.0	7.18	52.5	YES	300
8	1.5	1185	1777.5	8.0	7.17	49.4	YES	300
9	1.47	1185	1742.0	8.0	7.16	49.1	YES	300
10	1.49	1185	1765.7	7.0	7.15	52.4	YES	300
11	1.51	1185	1789.4	7.0	7.17	52.9	YES	300
12	1.48	1185	1753.8	7.0	7.16	52.6	YES	300
13	1.53	1185	1813.1	7.0	7.20	53.6	YES	300
14	1.41	1185	1670.9	7.0	7.18	52.5	YES	290
15	1.39	1185	1647.2	8.0	7.18	49.0	YES	290
16	1.42	1185	1682.7	8.0	7.21	49.7	YES	290
17	1.4	1185	1659.0	7.0	7.22	53.2	YES	290
18	1.38	1185	1635.3	7.0	7.21	52.9	YES	290
19	1.43	1185	1694.6	6.0	7.24	57.5	YES	290
20	1.48	1185	1753.8	5.0	7.23	61.7	YES	290
21	1.49	1185	1765.7	5.0	7.22	61.6	YES	290
22	1.4	1185	1659.0	5.0	7.21	60.7	YES	290
23	1.42	1185	1682.7	5.0	7.21	60.8	YES	290
24	1.41	1185	1670.9	5.0	7.22	61.0	YES	290
25	1.43	1185	1694.6	4.0	7.18	64.5	YES	290
26	1.42	1185	1682.7	4.0	7.20	64.9	YES	290
27	1.38	1185	1635.3	4.0	7.17	63.9	YES	290
28	1.37	1185	1623.5	4.0	7.19	64.3	YES	290
29	1.35	1185	1599.8	4.0	7.16	63.4	YES	290
30	1.39	1185	1647.2	3.0	7.17	68.5	YES	290
31	1.42	1185	1682.7	3.0	7.19	69.2	YES	290

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dwp.dmc@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350