

OHA - Drinking Water Services - Surface Water Quality Data Form

Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems


County:

Lane

Month/Year:

24-Apr

System Name: Row River Valley Water District ID#: 41 01515							WTP : TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03
3	0.04	0.03	0.03	0.03	0.03	0.03	0.03
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03
12	0.03	0.03	0.03	0.03	0.03	0.03	0.03
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03
14	0.03	0.03	0.03	0.03	0.03	0.30	0.03
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings ≤ 1 NTU? ²	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?	
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	
Notes:		James D Eckstine SIGNATURE:  541-946-1655		
		May-24		

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

A

Disinfection Giardia Log

Inactiv:

1.0

System Name: Row River Valley Water Dis ID#: 41 01515 Month/Year: 24-Apr

	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.49	1185	1765.7	8.0	7.25	50.8	YES	290
2	1.49	1185	1765.7	10.0	7.26	44.6	YES	290
3	1.55	1185	1836.8	9.0	7.21	47.2	YES	290
4	1.73	1185	2050.1	7.0	7.21	55.1	YES	290
5	1.76	1185	2085.6	7.0	7.25	56.1	YES	290
6	1.78	1185	2109.3	7.0	7.23	55.8	YES	290
7	1.8	1185	2133.0	7.0	7.28	56.9	YES	200
8	1.68	1185	1990.8	9.0	7.30	49.5	YES	200
9	1.7	1185	2014.5	8.0	7.27	52.4	YES	200
10	1.75	1185	2073.8	9.0	7.25	49.0	YES	200
11	1.68	1185	1990.8	8.0	7.20	51.0	YES	200
12	1.7	1185	2014.5	10.0	7.19	44.6	YES	200
13	1.71	1185	2026.4	9.0	7.17	47.4	YES	200
14	1.59	1185	1884.2	9.0	7.21	47.4	YES	200
15	1.55	1185	1836.8	9.0	7.18	46.7	YES	200
16	1.62	1185	1919.7	8.0	7.19	50.5	YES	200
17	1.62	1185	1919.7	7.0	7.17	53.6	YES	200
18	1.7	1185	2014.5	7.0	7.18	54.3	YES	200
19	2.01	1185	2381.9	9.0	7.23	50.1	YES	200
20	2.05	1185	2429.3	9.0	7.21	50.0	YES	200
21	1.64	1185	1943.4	8.0	7.18	50.4	YES	200
22	1.45	1185	1718.3	8.0	7.17	49.2	YES	200
23	1.48	1185	1753.8	9.0	7.19	46.5	YES	200
24	1.51	1185	1789.4	11.0	7.20	41.0	YES	200
25	1.5	1185	1777.5	10.0	7.19	43.6	YES	200
26	1	1185	1185.0	9.0	7.24	44.8	YES	200
27	0.92	1185	1090.2	9.0	7.18	43.5	YES	200
28	0.89	1185	1054.7	9.0	7.20	43.6	YES	280
29	1.01	1185	1196.9	9.0	7.21	44.4	YES	280
30	1.05	1185	1244.3	8.0	7.22	47.8	YES	280

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018