


OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County:	Lane
Month/Year:	24-May

System Name: Row River Valley Water District ID#: 41 01515							WTP : TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03
3	0.04	0.03	0.03	0.03	0.03	0.03	0.03
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03
12	0.03	0.03	0.03	0.03	0.03	0.03	0.03
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03
14	0.03	0.03	0.03	0.03	0.03	0.30	0.03
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03
31	0.03	0.03	0.03	0.03	0.03	0.03	0.03

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings \leq 1 NTU? ²	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl ₂ residual at entry point \geq 0.2 mg/l?	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings \leq 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No			

Notes:	James D Eckstine
	SIGNATURE: 
	541-946-1655
	Jun-24

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

A

System Name:	Row River Valley Water Dis	ID#:	41	01515	Month/Year:	24-May	Disinfection Giardia Log	
							Inactiv:	1.0

	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.14	1185	1350.9	9.0	7.18	44.6	YES	290
2	1.2	1185	1422.0	9.0	7.19	45.0	YES	290
3	1.22	1185	1445.7	9.0	7.16	44.7	YES	290
4	1.19	1185	1410.2	9.0	7.23	45.6	YES	290
5	1.22	1185	1445.7	8.0	7.26	49.4	YES	290
6	1.39	1185	1647.2	9.0	7.24	46.8	YES	290
7	1.44	1185	1706.4	8.0	7.23	50.2	YES	200
8	1.65	1185	1955.3	10.0	7.21	44.7	YES	200
9	1.66	1185	1967.1	10.0	7.20	44.6	YES	200
10	1.63	1185	1931.6	12.0	7.19	38.8	YES	200
11	1.65	1185	1955.3	11.0	7.18	41.4	YES	200
12	1.63	1185	1931.6	12.0	7.17	38.6	YES	200
13	1.6	1185	1896.0	11.0	7.15	40.7	YES	200
14	1.59	1185	1884.2	12.0	7.21	38.9	YES	200
15	1.58	1185	1872.3	12.0	7.17	38.3	YES	200
16	1.55	1185	1836.8	13.0	7.16	35.2	YES	200
17	1.56	1185	1848.6	13.0	7.15	35.1	YES	200
18	1.53	1185	1813.1	11.0	7.14	40.3	YES	200
19	1.54	1185	1824.9	11.0	7.15	40.5	YES	200
20	1.53	1185	1813.1	10.0	7.14	43.0	YES	200
21	1.54	1185	1824.9	10.0	7.17	43.5	YES	200
22	1.68	1185	1990.8	11.0	7.18	41.5	YES	200
23	1.75	1185	2073.8	10.0	7.20	45.0	YES	200
24	1.76	1185	2085.6	10.0	7.21	45.2	YES	200
25	1.77	1185	2097.5	11.0	7.16	41.7	YES	200
26	1.81	1185	2144.9	10.0	7.15	44.5	YES	200
27	1.87	1185	2216.0	11.0	7.17	42.3	YES	200
28	1.89	1185	2239.7	13.0	7.18	36.8	YES	280
29	1.93	1185	2287.1	11.0	7.19	42.9	YES	280
30	1.95	1185	2310.8	13.0	7.18	37.1	YES	280
31	1.9	1185	2251.5	11.0	7.17	42.4	YES	280

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018