


OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County:	Lane
Month/Year:	24-Aug

System Name: Row River Valley Water District ID#: 41 01515							WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]	
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
12	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
14	0.03	0.03	0.03	0.03	0.03	0.30	0.03	
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
31	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
Slow Sand/Membrane/DE Filtration/Unfiltered					Monthly Summary (Answer Yes or No)			
95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="checkbox"/> Yes / No					CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No		All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No	
All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / No								
Notes:					James D Eckstine			
SIGNATURE: 					Sep-24			
541-946-1655								

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - :

A

System Name: Row River Valley Water Dis ID#: 41 01515 Month/Year: 24-Aug

Disinfection Giardia Log

Inactiv:

1.0

	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.62	1185	1919.7	18.0	7.16	25.4	YES	290
2	1.65	1185	1955.3	19.0	7.15	23.7	YES	290
3	1.65	1185	1955.3	19.0	7.15	23.7	YES	290
4	1.67	1185	1979.0	20.0	7.16	22.3	YES	290
5	1.71	1185	2026.4	21.0	7.16	21.0	YES	290
6	1.69	1185	2002.7	20.0	7.14	22.2	YES	290
7	1.57	1185	1860.5	19.0	7.14	23.4	YES	290
8	1.1	1185	1303.5	18.0	7.14	23.7	YES	290
9	1.19	1185	1410.2	20.0	7.15	21.0	YES	290
10	1.23	1185	1457.6	19.0	7.15	22.6	YES	290
11	1.25	1185	1481.3	19.0	7.18	22.9	YES	290
12	1.23	1185	1457.6	19.0	7.19	22.9	YES	290
13	1.3	1185	1540.5	18.0	7.16	24.5	YES	290
14	1.35	1185	1599.8	18.0	7.18	24.8	YES	290
15	1.46	1185	1730.1	17.0	7.15	26.6	YES	290
16	1.53	1185	1813.1	17.0	7.16	26.9	YES	290
17	1.59	1185	1884.2	17.0	7.14	26.8	YES	290
18	1.5	1185	1777.5	17.0	7.16	26.8	YES	290
19	1.3	1185	1540.5	17.0	7.19	26.5	YES	290
20	1.25	1185	1481.3	17.0	7.17	26.1	YES	290
21	1.31	1185	1552.4	19.0	7.18	23.1	YES	290
22	1.34	1185	1587.9	17.0	7.15	26.2	YES	290
23	1.3	1185	1540.5	16.0	7.14	27.8	YES	290
24	1.29	1185	1528.7	15.0	7.17	30.0	YES	290
25	1.25	1185	1481.3	15.0	7.16	29.7	YES	290
26	1.35	1185	1599.8	15.0	7.17	30.2	YES	290
27	1.41	1185	1670.9	16.0	7.16	28.3	YES	290
28	1.42	1185	1682.7	16.0	7.16	28.4	YES	290
29	1.45	1185	1718.3	15.0	7.15	30.3	YES	290
30	1.48	1185	1753.8	16.0	7.17	28.7	YES	290
31	1.44	1185	1706.4	16.0	7.15	28.3	YES	290

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018