

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Lane**  
 Month/Year: **24-Sep**


System Name: **Row River Valley Water District ID#: 41 01515** WTP: **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03
12	0.03	0.03	0.03	0.03	0.03	0.03	0.03
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03
14	0.03	0.03	0.03	0.03	0.03	0.30	0.03
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup>	<b>Yes / No</b>	CT's met everyday? (see back)	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<b>Yes / No</b>	<b>Yes / No</b>	<b>Yes / No</b>

Notes:

**James D Eckstine**

SIGNATURE:  **Oct-24**

541-946-1655

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.



OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A  
 Disinfection *Giardia* Log Inactiv: 1.0

System Name: Row River Vally Water Dis ID#: 41 01515 Month/Year: 24-Sep

	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.44	1185	1706.4	16.0	7.15	28.3	YES	265
2	1.45	1185	1718.3	17.0	7.18	26.8	YES	265
3	1.4	1185	1659.0	17.0	7.14	26.3	YES	265
4	1.44	1185	1706.4	148.0	7.18	-0.8	YES	265
5	1.42	1185	1682.7	17.0	7.19	26.8	YES	265
6	1.44	1185	1706.4	18.0	7.20	25.2	YES	265
7	1.4	1185	1659.0	18.0	7.19	25.0	YES	265
8	1.39	1185	1647.2	18.0	7.21	25.2	YES	265
9	1.41	1185	1670.9	17.0	7.18	26.7	YES	265
10	1.42	1185	1682.7	15.0	7.16	30.3	YES	265
11	1.11	1185	1315.4	15.0	7.17	29.4	YES	265
12	1.1	1185	1303.5	15.0	7.20	29.7	YES	265
13	1.14	1185	1350.9	15.0	7.18	29.6	YES	265
14	1.19	1185	1410.2	14.0	7.17	31.7	YES	265
15	1.21	1185	1433.9	16.0	7.18	27.9	YES	265
16	1.3	1185	1540.5	14.0	7.19	32.3	YES	265
17	1.35	1185	1599.8	4.0	7.14	63.0	YES	265
18	1.42	1185	1682.7	15.0	7.17	30.4	YES	265
19	1.47	1185	1742.0	15.0	7.20	31.0	YES	265
20	1.59	1185	1884.2	14.0	7.18	33.3	YES	265
21	1.61	1185	1907.9	12.0	7.16	38.3	YES	265
22	1.69	1185	2002.7	17.0	7.15	27.3	YES	265
23	1.65	1185	1955.3	16.0	7.18	29.3	YES	265
24	1.5	1185	1777.5	15.0	7.18	30.8	YES	265
25	1.17	1185	1386.5	15.0	7.17	29.6	YES	265
26	7.14	1185	8460.9	15.0	7.17	58.2	YES	265
27	7.19	1185	8520.2	16.0	7.19	55.2	YES	265
28	7.16	1185	8484.6	16.0	7.16	54.4	YES	265
29	1.35	1185	1599.8	14.0	7.16	32.2	YES	265
30	1.33	1185	1576.1	12.0	7.13	36.8	YES	265

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018