


OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Lane
 Month/Year: Jan-17
 WTP: TP - A

System Name:	Row River Water Dist		ID#: 41	01515		WTP: TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03
12	0.03	0.03	0.03	0.03	0.03	0.03	0.03
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03
14	0.03	0.03	0.03	0.03	0.03	0.03	0.03
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03
31	0.03	0.03	0.03	0.03	0.03	0.03	0.03

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ²	YES	CT's met everyday? (see back)	All Cl2 residual at entry point \geq 0.2 mg/l?
All daily turbidity readings \leq 5 NTU?	YES	YES	YES
Notes:		James D Eckstine	
		SIGNATURE: 	2/10/21
		541-946-1655	T-08619

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP-: A
 Disinfection *Giardia* Log Inactiv: 1.0

System Name: Row River Water Dist ID#: 41 01515 Month/Year: Jan-21

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.39	1185	1647.2	8.0	7.32	51.5	YES	250
2	1.36	1185	1611.6	8.0	7.24	49.9	YES	250
3	1.39	1185	1647.2	8.0	7.26	50.4	YES	250
4	1.34	1185	1587.9	8.0	7.26	50.1	YES	250
5	1.29	1185	1528.7	8.0	7.31	50.7	YES	250
6	1.25	1185	1481.3	8.0	7.28	50.0	YES	250
7	1.28	1185	1516.8	8.0	7.31	50.7	YES	250
8	1.32	1185	1564.2	7.0	7.33	54.8	YES	250
9	1.34	1185	1587.9	7.0	7.32	54.8	YES	250
10	1.36	1185	1611.6	8.0	7.29	50.8	YES	250
11	1.34	1185	1587.9	8.0	7.27	50.3	YES	250
12	1.34	1185	1587.9	8.0	7.27	50.3	YES	250
13	1.36	1185	1611.6	8.0	7.31	51.2	YES	250
14	1.34	1185	1587.9	8.0	7.28	50.5	YES	250
15	1.3	1185	1540.5	9.0	7.19	45.5	YES	250
16	1.41	1185	1670.9	9.0	7.21	46.4	YES	250
17	1.46	1185	1730.1	8.0	7.21	49.9	YES	250
18	1.44	1185	1706.4	8.0	7.18	49.3	YES	250
19	1.46	1185	1730.1	7.0	7.19	53.0	YES	250
20	1.47	1185	1742.0	7.0	7.18	52.9	YES	250
21	1.31	1185	1552.4	6.0	7.20	55.9	YES	250
22	1.27	1185	1505.0	6.0	7.21	55.9	YES	250
23	1.24	1185	1469.4	6.0	7.21	55.7	YES	250
24	1.28	1185	1516.8	6.0	7.24	56.5	YES	250
25	1.29	1185	1528.7	5.0	7.23	60.4	YES	250
26	1.32	1185	1564.2	5.0	7.20	59.9	YES	250
27	1.38	1185	1635.3	5.0	7.18	59.9	YES	250
28	1.35	1185	1599.8	5.0	7.20	60.1	YES	250
29	1.34	1185	1587.9	5.0	7.21	60.3	YES	250
30	1.36	1185	1611.6	5.0	7.21	60.4	YES	250
31	1.37	1185	1623.5	6.0	7.24	57.1	YES	250

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.