


OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Lane
 Month/Year: Mar-21

System Name:	Row River Water Dist		ID#: 41	01515		WTP: TP -		A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]	
1	0.03	0.03	0.03	0.03	0.03	0.03		0.03
2	0.03	0.03	0.03	0.03	0.03	0.03		0.03
3	0.03	0.03	0.03	0.03	0.03	0.03		0.03
4	0.03	0.03	0.03	0.03	0.03	0.03		0.03
5	0.03	0.03	0.03	0.03	0.03	0.03		0.03
6	0.03	0.03	0.03	0.03	0.03	0.03		0.03
7	0.03	0.03	0.03	0.03	0.03	0.03		0.03
8	0.03	0.03	0.03	0.03	0.03	0.03		0.03
9	0.03	0.03	0.03	0.03	0.03	0.03		0.03
10	0.03	0.03	0.03	0.03	0.03	0.03		0.03
11	0.03	0.03	0.03	0.03	0.03	0.03		0.03
12	0.03	0.03	0.03	0.03	0.03	0.03		0.03
13	0.03	0.03	0.03	0.03	0.03	0.03		0.03
14	0.03	0.03	0.03	0.03	0.03	0.03		0.03
15	0.03	0.03	0.03	0.03	0.03	0.03		0.03
16	0.03	0.03	0.03	0.03	0.03	0.03		0.03
17	0.03	0.03	0.03	0.03	0.03	0.03		0.03
18	0.03	0.03	0.03	0.03	0.03	0.03		0.03
19	0.03	0.03	0.03	0.03	0.03	0.03		0.03
20	0.03	0.03	0.03	0.03	0.03	0.03		0.03
21	0.03	0.03	0.03	0.03	0.03	0.03		0.03
22	0.03	0.03	0.03	0.03	0.03	0.03		0.03
23	0.03	0.03	0.03	0.03	0.03	0.03		0.03
24	0.03	0.03	0.03	0.03	0.03	0.03		0.03
25	0.03	0.03	0.03	0.03	0.03	0.03		0.03
26	0.03	0.03	0.03	0.03	0.03	0.03		0.03
27	0.03	0.03	0.03	0.03	0.03	0.03		0.03
28	0.03	0.03	0.03	0.03	0.03	0.03		0.03
29	0.03	0.03	0.03	0.03	0.03	0.03		0.03
30	0.03	0.03	0.03	0.03	0.03	0.03		0.03
31	0.03	0.03	0.03	0.03	0.03	0.03		0.03

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ² YES	CT's met everyday? (see back) YES	All Cl2 residual at entry point \geq 0.2 mg/l? YES
All daily turbidity readings \leq 5 NTU? YES		
Notes:	James D Eckstine 	
	SIGNATURE:	4/9/21
	541-946-1655	T-08619

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :	A
Disinfection <i>Giardia</i> Log Inactiv:	1.0

System Name: Row River Water Dist ID#: 41 01515 Month/Year: Mar-21

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.6	1185	1896.0	5.0	7.20	61.9	YES	295
2	1.4	1185	1659.0	5.0	7.19	60.3	YES	295
3	1.46	1185	1730.1	6.0	0.18	7.7	YES	295
4	1.53	1185	1813.1	6.0	7.19	57.2	YES	295
5	1.48	1185	1753.8	6.0	7.20	57.0	YES	295
6	1.59	1185	1884.2	6.0	7.17	57.1	YES	295
7	1.64	1185	1943.4	6.0	7.19	57.9	YES	295
8	1.42	1185	1682.7	5.0	7.19	60.4	YES	295
9	1.45	1185	1718.3	6.0	7.21	57.0	YES	295
10	1.4	1185	1659.0	5.0	7.19	60.3	YES	295
11	1.39	1185	1647.2	5.0	7.18	60.0	YES	295
12	1.41	1185	1670.9	5.0	7.18	60.1	YES	295
13	1.4	1185	1659.0	5.0	7.17	59.8	YES	295
14	1.38	1185	1635.3	6.0	7.17	55.8	YES	295
15	1.37	1185	1623.5	6.0	7.16	55.5	YES	295
16	1.4	1185	1659.0	5.0	7.20	60.5	YES	295
17	1.39	1185	1647.2	5.0	7.15	59.3	YES	295
18	1.4	1185	1659.0	6.0	7.18	56.1	YES	295
19	1.43	1185	1694.6	6.0	7.20	56.7	YES	295
20	1.45	1185	1718.3	6.0	7.21	57.0	YES	295
21	1.4	1185	1659.0	7.0	7.18	52.5	YES	295
22	1.38	1185	1635.3	6.0	7.20	56.4	YES	295
23	1.32	1185	1564.2	6.0	7.14	54.8	YES	295
24	1.29	1185	1528.7	7.0	7.19	52.0	YES	295
25	1.26	1185	1493.1	6.0	7.21	55.8	YES	295
26	1.29	1185	1528.7	6.0	7.20	55.8	YES	295
27	1.36	1185	1611.6	6.0	7.15	55.3	YES	295
28	1.4	1185	1659.0	6.0	7.16	55.7	YES	295
29	1.48	1185	1753.8	6.0	7.19	56.8	YES	295
30	1.53	1185	1813.1	6.0	7.14	56.1	YES	295
31	1.49	1185	1765.7	6.0	7.11	55.3	YES	295

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013