


OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Lane
 Month/Year: May-21
 WTP: TP - A

System Name:	Row River Water Dist		ID#: 41	01515		WTP: TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03
12	0.03	0.03	0.03	0.03	0.03	0.03	0.03
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03
14	0.03	0.03	0.03	0.03	0.03	0.03	0.03
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03
31	0.03	0.03	0.03	0.03	0.03	0.03	0.03

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² YES	CT's met everyday? (see back) YES	All Cl2 residual at entry point ≥ 0.2 mg/l? YES
All daily turbidity readings ≤ 5 NTU? YES		
Notes:	James D Eckstine	
	SIGNATURE: 	6/9/21
	541-946-1655	T-08619

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP-: A

System Name: Row River Water Dist ID#: 41 01515 Month/Year: Sep-19

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.46	1185	1730.1	12.0	7.21	38.4	YES	260
2	1.45	1185	1718.3	12.0	7.20	38.2	YES	260
3	1.44	1185	1706.4	11.0	7.20	40.7	YES	260
4	1.4	1185	1659.0	12.0	7.18	37.7	YES	260
5	1.41	1185	1670.9	12.0	7.19	37.9	YES	260
6	1.39	1185	1647.2	12.0	7.22	38.2	YES	260
7	1.4	1185	1659.0	12.0	7.21	38.1	YES	260
8	1.43	1185	1694.6	11.0	7.20	40.7	YES	260
9	1.41	1185	1670.9	11.0	7.18	40.3	YES	260
10	1.42	1185	1682.7	11.0	7.18	40.3	YES	260
11	1.38	1185	1635.3	11.0	7.17	40.0	YES	260
12	1.4	1185	1659.0	11.0	7.18	40.2	YES	260
13	1.43	1185	1694.6	12.0	7.17	37.7	YES	260
14	1.52	1185	1801.2	13.0	7.16	35.0	YES	260
15	1.48	1185	1753.8	13.0	7.17	35.0	YES	260
16	1.46	1185	1730.1	14.0	7.17	32.7	YES	260
17	1.44	1185	1706.4	14.0	7.16	32.5	YES	265
18	1.42	1185	1682.7	14.0	7.17	32.5	YES	265
19	1.49	1185	1765.7	13.0	7.19	35.3	YES	265
20	1.47	1185	1742.0	11.0	7.20	40.8	YES	265
21	1.49	1185	1765.7	10.0	7.21	43.9	YES	265
22	1.26	1185	1493.1	10.0	7.18	42.3	YES	265
23	1.24	1185	1469.4	11.0	7.16	39.3	YES	265
24	1.22	1185	1445.7	13.0	7.20	34.4	YES	265
25	1.26	1185	1493.1	13.0	7.20	34.5	YES	265
26	1.27	1185	1505.0	12.0	7.17	37.0	YES	265
27	1.24	1185	1469.4	12.0	7.17	36.9	YES	265
28	1.26	1185	1493.1	11.0	7.18	39.6	YES	265
29	1.41	1185	1670.9	13.0	7.19	35.0	YES	265
30	1.43	1185	1694.6	14.0	7.20	32.9	YES	265
31	1.42	1185	1682.7	14.0	7.19	32.8	YES	265

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013