

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Lane
 Month/Year: Jun-21
 WTP: TP - A

System Name: Row River Water Dist ID#: 41 01515

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03
12	0.03	0.03	0.03	0.03	0.03	0.03	0.03
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03
14	0.03	0.03	0.03	0.03	0.03	0.03	0.03
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03
31	0.03	0.03	0.03	0.03	0.03	0.03	0.03

Slow Sand/Membrane/DE Filtration/Unfiltered
 95% of daily turbidity readings \leq 1 NTU? ² **YES**
 All daily turbidity readings \leq 5 NTU? **YES**

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) YES	All Cl ₂ residual at entry point \geq 0.2 mg/l? YES
---	--

Notes:

James D Eckstine
 SIGNATURE: *[Signature]*
 541-946-1655
 7/10/21
 T-08619

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A
 Disinfection *Giardia* Log Inactiv: 1.0

System Name: Row River Water Dist ID#: 41 01515 Month/Year: Jun-21

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.37	1185	1623.5	14.0	7.22	33.0	YES	275
2	1.5	1185	1777.5	15.0	7.23	31.4	YES	275
3	1.44	1185	1706.4	15.0	7.19	30.7	YES	275
4	1.43	1185	1694.6	15.0	7.21	30.9	YES	275
5	1.42	1185	1682.7	14.0	7.22	33.1	YES	275
6	1.46	1185	1730.1	13.0	7.23	35.7	YES	275
7	1.49	1185	1765.7	13.0	7.22	35.7	YES	275
8	1.48	1185	1753.8	13.0	7.25	36.1	YES	280
9	1.44	1185	1706.4	13.0	7.27	36.2	YES	280
10	1.45	1185	1718.3	12.0	7.25	38.9	YES	280
11	1.5	1185	1777.5	12.0	7.25	39.1	YES	280
12	1.62	1185	1919.7	12.0	7.27	39.9	YES	280
13	1.64	1185	1943.4	13.0	7.23	36.5	YES	280
14	1.59	1185	1884.2	12.0	7.22	39.1	YES	280
15	1.52	1185	1801.2	13.0	7.26	36.4	YES	280
16	1.51	1185	1789.4	14.0	7.24	33.7	YES	280
17	1.53	1185	1813.1	14.0	7.27	34.2	YES	280
18	1.5	1185	1777.5	15.0	7.24	31.5	YES	280
19	1.48	1185	1753.8	15.0	7.26	31.7	YES	285
20	1.47	1185	1742.0	15.0	7.27	31.8	YES	280
21	1.45	1185	1718.3	16.0	7.24	29.3	YES	280
22	1.44	1185	1706.4	16.0	7.22	29.1	YES	280
23	1.49	1185	1765.7	17.0	7.26	27.8	YES	280
24	1.51	1185	1789.4	17.0	7.26	27.8	YES	280
25	1.55	1185	1836.8	8.0	7.25	51.2	YES	280
26	1.58	1185	1872.3	18.0	7.23	25.9	YES	280
27	1.55	1185	1836.8	18.0	7.20	25.6	YES	280
28	1.51	1185	1789.4	19.0	7.19	23.7	YES	280
29	1.39	1185	1647.2	19.0	7.22	23.6	YES	280
30	1.5	1185	1777.5	18.0	7.25	25.9	YES	280
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.