


OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Lane
 Month/Year: Aug-21

System Name:	Row River Water Dist	ID#: 41	01515	WTP: TP - A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03
12	0.03	0.03	0.03	0.03	0.03	0.03	0.03
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03
14	0.03	0.03	0.03	0.03	0.03	0.03	0.03
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03
31	0.03	0.03	0.03	0.03	0.03	0.03	0.03

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ²	YES	CT's met everyday? (see back)
All daily turbidity readings \leq 5 NTU?	YES	All Cl ₂ residual at entry point \geq 0.2 mg/l?
		YES
Notes:	James D Eckstine	
	SIGNATURE: 	9/1/21
	541-946-1655	T-08619

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - :	A
Disinfection <i>Giardia</i> Log Inactiv:	1.0

System Name: Row River Water Dist ID#: 41 01515 Month/Year: Aug-21

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.26	1185	1493.1	20.0	7.19	21.5	YES	285
2	1.16	1185	1374.6	22.0	7.18	18.5	YES	285
3	1.21	1185	1433.9	22.0	7.19	18.7	YES	285
4	1.2	1185	1422.0	21.0	7.18	19.9	YES	285
5	1.21	1185	1433.9	20.0	7.21	21.6	YES	285
6	1.16	1185	1374.6	19.0	7.22	23.0	YES	285
7	1.17	1185	1386.5	19.0	7.21	23.0	YES	285
8	1.22	1185	1445.7	20.0	7.23	21.8	YES	285
9	1.15	1185	1362.8	18.0	7.21	24.5	YES	285
10	1.2	1185	1422.0	19.0	7.20	23.0	YES	285
11	1.21	1185	1433.9	19.0	7.19	22.9	YES	285
12	1.23	1185	1457.6	20.0	7.21	21.6	YES	285
13	1.2	1185	1422.0	20.0	7.20	21.5	YES	285
14	1.16	1185	1374.6	20.0	7.19	21.3	YES	285
15	1.16	1185	1374.6	21.0	7.19	19.9	YES	285
16	1.2	1185	1422.0	21.0	7.19	20.0	YES	285
17	1.17	1185	1386.5	21.0	7.19	19.9	YES	285
18	1.15	1185	1362.8	19.0	7.17	22.6	YES	285
19	1.15	1185	1362.8	18.0	7.18	24.2	YES	285
20	1.14	1185	1350.9	19.0	7.19	22.7	YES	285
21	1.09	1185	1291.7	18.0	7.19	24.2	YES	285
22	1.26	1185	1493.1	18.0	7.18	24.5	YES	285
23	1.19	1185	1410.2	17.0	7.18	26.0	YES	285
24	1.21	1185	1433.9	16.0	7.18	27.9	YES	285
25	1.24	1185	1469.4	16.0	7.17	27.9	YES	285
26	1.26	1185	1493.1	16.0	7.18	28.1	YES	285
27	1.26	1185	1493.1	16.0	7.18	28.1	YES	285
28	1.24	1185	1469.4	16.0	7.17	27.9	YES	285
29	1.21	1185	1433.9	16.0	7.17	27.8	YES	285
30	1.19	1185	1410.2	17.0	7.17	25.9	YES	285
31	1.15	1185	1362.8	17.0	7.44	28.5	YES	285

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.