


OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Lane**
 Month/Year: **22-Mar**
 WTP : TP - **A**

System Name: **Row River Valley Water District** ID#: **41 01515**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03
12	0.03	0.03	0.03	0.03	0.03	0.03	0.03
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03
14	0.03	0.03	0.03	0.03	0.03	0.03	0.03
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03
31	0.03	0.03	0.03	0.03	0.03	0.03	0.03

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No

Notes:	James D Eckstine	
	SIGNATURE: 	Apr-22
	541-946-1655	T08619

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A
 Disinfection *Giardia* Log Inactiv: 1.0

System Name: Row River Vally Water Dis ID#: 41 01515 Month/Year: 22-Mar

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.49	1185	1765.7	5.0	7.49	67.9	YES	
2	1.41	1185	1670.9	6.0	7.41	61.0	YES	
3	1.36	1185	1611.6	6.0	7.46	61.8	YES	
4	1.35	1185	1599.8	7.0	7.45	57.5	YES	
5	1.43	1185	1694.6	7.0	7.48	58.6	YES	
6	1.45	1185	1718.3	6.0	7.51	63.6	YES	
7	1.48	1185	1753.8	6.0	7.50	63.6	YES	
8	1.5	1185	1777.5	6.0	7.50	63.7	YES	
9	1.5	1185	1777.5	6.0	7.50	63.7	YES	
10	1.52	1185	1801.2	6.0	7.52	64.3	YES	
11	1.5	1185	1777.5	5.0	7.50	68.2	YES	
12	1.53	1185	1813.1	5.0	7.53	69.2	YES	
13	1.52	1185	1801.2	5.0	7.53	69.1	YES	
14	1.5	1185	1777.5	6.0	7.50	63.7	YES	
15	1.47	1185	1742.0	7.0	7.52	59.8	YES	
16	1.5	1185	1777.5	7.0	7.51	59.8	YES	
17	1.52	1185	1801.2	7.0	7.53	60.3	YES	
18	1.52	1185	1801.2	7.0	7.50	59.7	YES	
19	1.54	1185	1824.9	8.0	7.48	55.5	YES	
20	1.52	1185	1801.2	8.0	7.50	55.8	YES	
21	1.48	1185	1753.8	8.0	7.47	54.9	YES	
22	1.53	1185	1813.1	8.0	7.51	56.0	YES	
23	1.55	1185	1836.8	9.0	7.49	52.1	YES	
24	1.49	1185	1765.7	9.0	7.49	51.8	YES	
25	1.51	1185	1789.4	9.0	7.48	51.7	YES	
26	1.53	1185	1813.1	9.0	7.48	51.8	YES	
27	1.52	1185	1801.2	10.0	7.52	49.1	YES	
28	1.5	1185	1777.5	10.0	7.50	48.7	YES	
29	1.48	1185	1753.8	10.0	7.49	48.4	YES	
30	1.47	1185	1742.0	9.0	7.50	51.8	YES	
31	1.44	1185	1706.4	9.0	7.48	51.3	YES	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350