

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems


County: **Lane**
 Month/Year: **Apr-22**

System Name: **Row River Water District** ID#: **41 01515** WTP: **TP - A**

| Day | 12 AM [NTU] | 4 AM [NTU] | 8 AM [NTU] | NOON [NTU] | 4 PM [NTU] | 8 PM [NTU] | Highest Reading of the day ¹ [NTU] |
|-----|-------------|------------|------------|------------|------------|------------|---|
| 1 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 2 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 3 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 4 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 5 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 6 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 7 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 8 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 9 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 10 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 11 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 12 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 13 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 14 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 15 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 16 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 17 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 18 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 19 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 20 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 21 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 22 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 23 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 24 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 25 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 26 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 27 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 28 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 29 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |
| 30 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 |

| Slow Sand/Membrane/DE Filtration/Unfiltered | | Monthly Summary (Answer Yes or No) | |
|--|----------|------------------------------------|--|
| 95% of daily turbidity readings \leq 1 NTU? ² | Yes / No | CT's met everyday? (see back) | All Cl ₂ residual at entry point \geq 0.2 mg/l? |
| All daily turbidity readings \leq 5 NTU? | Yes / No | Yes / No | Yes / No |

Notes:

| | |
|---|----------|
| James Eckstine | |
| SIGNATURE:  | 5/2/2022 |
| 541-946-1655 | T08619 |

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : A

System Name: Row River Water Dis ID#: 41 01515 Month/Year: 22-Apr Disinfection *Giardia* Log Inactiv: 1.0

| Date / Time | Minimum Cl ₂ Residual at 1st User (C) ³ | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? ³ | Peak Hourly Demand Flow |
|-------------|---|------------------|-----------|-------|------|-------------|----------------------|-------------------------|
| | [ppm or mg/l] | [minutes] | C X T | [° C] | | formula | Yes / No | [GPM] |
| 1 | 1.47 | 1185 | 1742.0 | 8.0 | 7.47 | 54.9 | Yes | 245 |
| 2 | 1.45 | 1185 | 1718.3 | 8.0 | 7.45 | 54.3 | Yes | 245 |
| 3 | 1.43 | 1185 | 1694.6 | 8.0 | 7.47 | 54.6 | Yes | 245 |
| 4 | 1.34 | 1185 | 1587.9 | 8.0 | 7.50 | 54.6 | Yes | 245 |
| 5 | 1.3 | 1185 | 1540.5 | 8.0 | 7.53 | 55.0 | Yes | 245 |
| 6 | 1.36 | 1185 | 1611.6 | 8.0 | 7.51 | 54.9 | Yes | 245 |
| 7 | 1.35 | 1185 | 1599.8 | 8.0 | 7.50 | 54.7 | Yes | 245 |
| 8 | 1.36 | 1185 | 1611.6 | 8.0 | 7.49 | 54.6 | Yes | 245 |
| 9 | 1.35 | 1185 | 1599.8 | 9.0 | 7.45 | 50.2 | Yes | 245 |
| 10 | 1.38 | 1185 | 1635.3 | 7.0 | 7.50 | 58.7 | Yes | 245 |
| 11 | 1.29 | 1185 | 1528.7 | 6.0 | 7.52 | 62.6 | Yes | 245 |
| 12 | 1.3 | 1185 | 1540.5 | 6.0 | 7.54 | 63.2 | Yes | 245 |
| 13 | 1.37 | 1185 | 1623.5 | 6.0 | 7.53 | 63.5 | Yes | 245 |
| 14 | 1.35 | 1185 | 1599.8 | 6.0 | 7.52 | 63.1 | Yes | 245 |
| 15 | 1.37 | 1185 | 1623.5 | 6.0 | 7.52 | 63.2 | Yes | 245 |
| 16 | 1.34 | 1185 | 1587.9 | 7.0 | 7.51 | 58.7 | Yes | 245 |
| 17 | 1.36 | 1185 | 1611.6 | 7.0 | 7.51 | 58.8 | Yes | 245 |
| 18 | 1.31 | 1185 | 1552.4 | 7.0 | 7.52 | 58.7 | Yes | 245 |
| 19 | 1.27 | 1185 | 1505.0 | 8.0 | 7.54 | 55.0 | Yes | 245 |
| 20 | 1.26 | 1185 | 1493.1 | 7.0 | 7.51 | 58.1 | Yes | 245 |
| 21 | 1.28 | 1185 | 1516.8 | 8.0 | 7.54 | 55.0 | Yes | 245 |
| 22 | 1.39 | 1185 | 1647.2 | 9.0 | 7.52 | 51.7 | Yes | 245 |
| 23 | 1.41 | 1185 | 1670.9 | 8.0 | 7.50 | 55.1 | Yes | 245 |
| 24 | 1.45 | 1185 | 1718.3 | 8.0 | 7.48 | 54.9 | Yes | 245 |
| 25 | 1.47 | 1185 | 1742.0 | 8.0 | 7.50 | 55.4 | Yes | 245 |
| 26 | 1.52 | 1185 | 1801.2 | 8.0 | 7.53 | 56.4 | Yes | 245 |
| 27 | 1.53 | 1185 | 1813.1 | 8.0 | 7.52 | 56.2 | Yes | 245 |
| 28 | 1.54 | 1185 | 1824.9 | 8.0 | 7.51 | 56.1 | Yes | 245 |
| 29 | 1.52 | 1185 | 1801.2 | 8.0 | 7.53 | 56.4 | Yes | 245 |
| 30 | 1.48 | 1185 | 1753.8 | 9.0 | 7.55 | 52.8 | Yes | 245 |
| 31 | | | | | | | | |

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350