


OHA - Drinking Water Services - Surface Water Quality Data Form							County:	Lane
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems							Month/Year:	May-22
System Name: Row River Water District				ID#: 41	01515		WTP: TP -	A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]	
1	0.03	0.03	0.03	0.03	0.03	0.03		0.03
2	0.03	0.03	0.03	0.03	0.03	0.03		0.03
3	0.03	0.03	0.03	0.03	0.03	0.03		0.03
4	0.03	0.03	0.03	0.03	0.03	0.03		0.03
5	0.03	0.03	0.03	0.03	0.03	0.03		0.03
6	0.03	0.03	0.03	0.03	0.03	0.03		0.03
7	0.03	0.03	0.03	0.03	0.03	0.03		0.03
8	0.03	0.03	0.03	0.03	0.03	0.03		0.03
9	0.03	0.03	0.03	0.03	0.03	0.03		0.03
10	0.03	0.03	0.03	0.03	0.03	0.03		0.03
11	0.03	0.03	0.03	0.03	0.03	0.03		0.03
12	0.03	0.03	0.03	0.03	0.03	0.03		0.03
13	0.03	0.03	0.03	0.03	0.03	0.03		0.03
14	0.03	0.03	0.03	0.03	0.03	0.03		0.03
15	0.03	0.03	0.03	0.03	0.03	0.03		0.03
16	0.03	0.03	0.03	0.03	0.03	0.03		0.03
17	0.03	0.03	0.03	0.03	0.03	0.03		0.03
18	0.03	0.03	0.03	0.03	0.03	0.03		0.03
19	0.03	0.03	0.03	0.03	0.03	0.03		0.03
20	0.03	0.03	0.03	0.03	0.03	0.03		0.03
21	0.03	0.03	0.03	0.03	0.03	0.03		0.03
22	0.03	0.03	0.03	0.03	0.03	0.03		0.03
23	0.03	0.03	0.03	0.03	0.03	0.03		0.03
24	0.03	0.03	0.03	0.03	0.03	0.03		0.03
25	0.03	0.03	0.03	0.03	0.03	0.03		0.03
26	0.03	0.03	0.03	0.03	0.03	0.03		0.03
27	0.03	0.03	0.03	0.03	0.03	0.03		0.03
28	0.03	0.03	0.03	0.03	0.03	0.03		0.03
29	0.03	0.03	0.03	0.03	0.03	0.03		0.03
30	0.03	0.03	0.03	0.03	0.03	0.03		0.03

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ²	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point \geq 0.2 mg/l?
All daily turbidity readings \leq 5 NTU?	Yes / No	Yes / No	Yes / No
Notes:		James Eckstine	
		SIGNATURE: 	6/2/2022
		541-946-1655	T08619

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

PAGE 1 of 2

Sent from my iPhone

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A
 Disinfection Giardia Log Inactive: 1.0

System Name: Row River Water Dis ID# 41 01515 Month/Year: 22-May

Date / Time	Millicon Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.44	1185	1706.4	10.0	7.52	48.7	Yes	245
2	1.47	1185	1742.0	8.0	7.53	56.1	Yes	245
3	1.43	1185	1694.6	9.0	7.48	51.2	Yes	245
4	1.41	1185	1670.9	10.0	7.46	47.5	Yes	245
5	1.37	1185	1623.5	9.0	7.46	50.5	Yes	245
6	1.39	1185	1647.2	9.0	7.43	50.1	Yes	245
7	1.3	1185	1540.5	8.0	7.53	55.0	Yes	245
8	1.38	1185	1635.3	8.0	7.55	55.9	Yes	245
9	1.29	1185	1528.7	8.0	7.53	54.9	Yes	245
10	1.31	1185	1552.4	8.0	7.52	54.8	Yes	245
11	1.34	1185	1587.9	8.0	7.52	55.0	Yes	245
12	1.33	1185	1576.1	8.0	7.50	54.6	Yes	245
13	1.3	1185	1540.5	8.0	7.52	54.8	Yes	245
14	1.29	1185	1528.7	8.0	7.55	55.3	Yes	245
15	1.28	1185	1516.8	9.0	7.53	51.3	Yes	245
16	1.27	1185	1505.0	9.0	7.50	50.7	Yes	245
17	1.28	1185	1516.8	9.0	7.48	50.4	Yes	245
18	1.29	1185	1528.7	9.0	7.42	49.4	Yes	245
19	1.32	1185	1564.2	9.0	7.46	50.2	Yes	245
20	1.3	1185	1540.5	9.0	7.46	50.1	Yes	245
21	1.29	1185	1528.7	10.0	7.44	46.5	Yes	245
22	1.35	1185	1599.8	11.0	7.41	43.4	Yes	245
23	1.3	1185	1540.5	11.0	7.40	43.0	Yes	245
24	1.25	1185	1481.3	9.0	7.38	46.4	Yes	245
25	1.4	1185	1659.0	12.0	7.38	40.4	Yes	245
26	1.49	1185	1765.7	12.0	7.40	41.1	Yes	245
27	1.47	1185	1742.0	12.0	7.37	40.6	Yes	245
28	1.48	1185	1753.6	11.0	7.36	43.6	Yes	245
29	1.33	1185	1576.1	10.0	7.41	46.2	Yes	245
30	1.25	1185	1481.3	10.0	7.38	45.3	Yes	245
31	1.27	1185	1505.0	10.0	7.34	44.8	Yes	245

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours. Revised July 2018
 Return by 10th of following month by email, fax, or mail to:
 dspl.dnce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350
 PAGE 2 of 2