


OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Lane
 Month/Year: Jun-22
 WTP: TP - A

System Name:	Row River Water District		ID#: 41	01515		WTP: TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03
12	0.03	0.03	0.03	0.03	0.03	0.03	0.03
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03
14	0.03	0.03	0.03	0.03	0.03	0.03	0.03
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes / No	Yes / No	Yes / No
Notes:		James Eckstine	
		SIGNATURE: 	7/3/2022
		541-946-1655	T08619

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A
 Disinfection *Giardia* Log Inactiv: 1.0

System Name: Row River Water Dis ID#: 41 01515 Month/Year: 22-Jun

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.32	1185	1564.2	12.0	7.36	39.8	Yes	300
2	1.35	1185	1599.8	11.0	7.33	42.2	Yes	300
3	1.33	1185	1576.1	12.0	7.31	39.1	Yes	300
4	1.32	1185	1564.2	11.0	7.32	41.9	Yes	300
5	1.26	1185	1493.1	11.0	7.29	41.2	Yes	300
6	1.34	1185	1587.9	11.0	7.33	42.1	Yes	300
7	1.37	1185	1623.5	12.0	7.32	39.5	Yes	300
8	1.4	1185	1659.0	12.0	7.33	39.7	Yes	300
9	1.44	1185	1706.4	12.0	7.35	40.2	Yes	300
10	1.47	1185	1742.0	12.0	7.31	39.8	Yes	300
11	1.26	1185	1493.1	12.0	7.43	40.5	Yes	300
12	1.11	1185	1315.4	12.0	7.41	39.5	Yes	300
13	1.19	1185	1410.2	11.0	7.42	42.7	Yes	300
14	1.32	1185	1564.2	10.0	7.40	46.0	Yes	300
15	1.39	1185	1647.2	11.0	7.37	43.0	Yes	320
16	1.36	1185	1611.6	11.0	7.35	42.5	Yes	320
17	1.35	1185	1599.8	11.0	7.36	42.6	Yes	320
18	1.4	1185	1659.0	11.0	7.38	43.2	Yes	320
19	1.39	1185	1647.2	11.0	7.36	42.8	Yes	320
20	1.44	1185	1706.4	11.0	7.37	43.2	Yes	320
21	1.42	1185	1682.7	12.0	7.37	40.4	Yes	330
22	1.45	1185	1718.3	14.0	7.37	35.2	Yes	330
23	1.47	1185	1742.0	13.0	7.38	37.8	Yes	330
24	1.45	1185	1718.3	13.0	7.38	37.7	Yes	330
25	1.47	1185	1742.0	15.0	7.36	32.8	Yes	330
26	1.45	1185	1718.3	16.0	7.34	30.4	Yes	330
27	1.52	1185	1801.2	17.0	7.36	28.9	Yes	330
28	1.5	1185	1777.5	15.0	7.39	33.3	Yes	330
29	1.57	1185	1860.5	15.0	7.35	33.1	Yes	330
30	1.46	1185	1730.1	16.0	7.36	30.7	Yes	330

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350