


OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Lane
 Month/Year: Jul-22
 WTP: TP - A

System Name:	Row River Water District		ID#: 41	01515		WTP: TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03
12	0.03	0.03	0.03	0.03	0.03	0.03	0.03
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03
14	0.03	0.03	0.03	0.03	0.03	0.03	0.03
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03
31	0.03	0.03	0.03	0.03	0.03	0.03	0.03

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ² <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl2 residual at entry point \geq 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No
All daily turbidity readings \leq 5 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No		
Notes:	James Eckstine	
	SIGNATURE: 	8/6/2022
	541-946-1655	T08619

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A
 Disinfection *Giardia* Log Inactiv: 1.0

System Name: Row River Water Dis ID#: 41 01515 Month/Year: 22-Jul

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.51	1185	1789.4	15.0	7.40	33.5	Yes	290
2	1.49	1185	1765.7	15.0	7.39	33.3	Yes	290
3	1.47	1185	1742.0	15.0	7.38	33.1	Yes	290
4	1.43	1185	1694.6	14.0	7.34	34.7	Yes	290
5	1.45	1185	1718.3	14.0	7.32	34.5	Yes	290
6	1.4	1185	1659.0	14.0	7.32	34.3	Yes	290
7	1.41	1185	1670.9	15.0	7.31	32.0	Yes	290
8	1.39	1185	1647.2	17.0	7.30	27.8	Yes	290
9	1.44	1185	1706.4	16.0	7.32	30.2	Yes	290
10	1.41	1185	1670.9	16.0	7.28	29.6	Yes	290
11	1.42	1185	1682.7	16.0	7.28	29.7	Yes	290
12	1.4	1185	1659.0	17.0	7.27	27.6	Yes	290
13	1.42	1185	1682.7	17.0	7.28	27.7	Yes	290
14	1.41	1185	1670.9	17.0	7.28	27.7	Yes	290
15	1.39	1185	1647.2	17.0	7.29	27.7	Yes	290
16	1.37	1185	1623.5	17.0	7.26	27.4	Yes	290
17	1.38	1185	1635.3	18.0	7.28	25.8	Yes	300
18	1.4	1185	1659.0	16.0	7.25	29.3	Yes	300
19	1.38	1185	1635.3	17.0	7.23	27.1	Yes	300
20	1.37	1185	1623.5	17.0	7.25	27.3	Yes	300
21	1.36	1185	1611.6	18.0	7.26	25.6	Yes	300
22	1.32	1185	1564.2	19.0	7.28	24.0	Yes	300
23	1.34	1185	1587.9	17.0	7.26	27.3	Yes	300
24	1.31	1185	1552.4	17.0	7.26	27.2	Yes	300
25	1.32	1185	1564.2	18.0	7.26	25.5	Yes	300
26	1.3	1185	1540.5	18.0	7.28	25.6	Yes	300
27	1.33	1185	1576.1	20.0	7.29	22.5	Yes	300
28	1.34	1185	1587.9	19.0	7.31	24.3	Yes	300
29	1.33	1185	1576.1	19.0	7.32	24.4	Yes	300
30	1.3	1185	1540.5	20.0	7.30	22.5	Yes	300
31	1.33	1185	1576.1	20.0	7.31	22.7	Yes	300

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350