

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Lane
 Month/Year: Oct-22

System Name: Row River Water District ID#: 41 01515 WTP: TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03
12	0.03	0.03	0.03	0.03	0.03	0.03	0.03
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03
14	0.03	0.03	0.03	0.03	0.03	0.03	0.03
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03
31	0.03	0.03	0.03	0.03	0.03	0.03	0.03

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
--	---

Notes: Cl2 machine Pump failed / 3 AM on 21st Went on Boiled water from 26 to until 29th for Rocky point to plant

James Eckstine
 SIGNATURE: *[Signature]* 11/1/2022
 541-946-1655 T08619

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A
 Disinfection *Giardia* Log Inactiv: 1.0

System Name: Row River Water Dis ID#: 41 01515 Month/Year: 22-Oct

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.49	1185	1765.7	15.0	7.20	31.0	Yes	290
2	1.45	1185	1718.3	15.0	7.21	31.0	Yes	290
3	1.23	1185	1457.6	15.0	7.19	30.0	Yes	290
4	1.19	1185	1410.2	14.0	7.21	32.2	Yes	290
5	1.08	1185	1279.8	14.0	7.19	31.5	Yes	290
6	1.06	1185	1256.1	14.0	7.18	31.3	Yes	290
7	1	1185	1185.0	14.0	7.18	31.1	Yes	290
8	1	1185	1185.0	14.0	7.21	31.5	Yes	290
9	1.02	1185	1208.7	14.0	7.19	31.3	Yes	290
10	1.02	1185	1208.7	14.0	7.22	31.7	Yes	290
11	0.98	1185	1161.3	13.0	7.18	33.2	Yes	290
12	1.3	1185	1540.5	13.0	7.20	34.7	Yes	290
13	1.43	1185	1694.6	13.0	7.18	34.9	Yes	290
14	1.48	1185	1753.8	13.0	7.16	34.9	Yes	290
15	1.56	1185	1848.6	13.0	7.15	35.1	Yes	290
16	1.51	1185	1789.4	13.0	7.14	34.7	Yes	290
17	1.48	1185	1753.8	13.0	7.17	35.0	Yes	300
18	1.45	1185	1718.3	12.0	7.16	37.7	Yes	300
19	1.58	1185	1872.3	12.0	7.18	38.5	Yes	300
20	1.24	1185	1469.4	12.0	7.23	37.7	Yes	300
21	0	1185	0.0	12.0	7.24	33.0	No	300
22	0	1185	0.0	11.0	7.25	35.3	No	300
23	0.58	1185	687.3	11.0	7.22	37.2	Yes	300
24	0.96	1185	1137.6	10.0	7.24	41.8	Yes	300
25	1.41	1185	1670.9	10.0	7.27	44.4	Yes	300
26	1.39	1185	1647.2	10.0	7.29	44.6	Yes	300
27	1.43	1185	1694.6	9.0	7.27	47.6	Yes	300
28	1.51	1185	1789.4	9.0	7.23	47.3	Yes	300
29	2.08	1185	2464.8	10.0	7.23	47.2	Yes	300
30	2.21	1185	2618.9	10.0	7.22	47.8	Yes	300
31	1.97	1185	2334.5	11.0	7.19	43.1	Yes	300

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350