

OHA - Drinking Water Services - Surface Water Quality Data Form  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Lane  
 Month/Year: 23-Feb

System Name: Row River Valley Water District ID#: 41 01515 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	0.03	0.04	0.04	0.04	0.04	0.03	0.04
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03
3	0.03	0.03	0.04	0.04	0.03	0.03	0.04
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03
12	0.03	0.03	0.03	0.03	0.03	0.03	0.03
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03
14	0.03	0.03	0.03	0.03	0.03	0.03	0.03
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:

James D Eckstine  
 SIGNATURE: *[Signature]* Mar-23  
 541-946-1655

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Row River Vally Water Dis ID#: 41 01515 Month/Year: 23-Feb Disinfection *Giardia* Log Inactiv: 1.0

	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.51	1185	1789.4	3.0	7.23	71.0	YES	300
2	1.53	1185	1813.1	3.0	7.20	70.4	YES	300
3	1.48	1185	1753.8	4.0	7.21	65.6	YES	300
4	7.17	1185	8496.5	5.0	7.19	119.5	YES	300
5	7.2	1185	8532.0	6.0	7.17	110.9	YES	300
6	7.18	1185	8508.3	6.0	7.15	109.8	YES	300
7	7.17	1185	8496.5	5.0	7.16	118.1	YES	300
8	1.37	1185	1623.5	6.0	7.23	56.9	YES	300
9	1.41	1185	1670.9	6.0	7.20	56.6	YES	300
10	1.45	1185	1718.3	6.0	7.21	57.0	YES	300
11	1.47	1185	1742.0	6.0	7.19	56.8	YES	300
12	1.43	1185	1694.6	6.0	7.17	56.1	YES	300
13	1.44	1185	1706.4	6.0	7.15	55.8	YES	300
14	1.41	1185	1670.9	4.0	7.16	63.9	YES	290
15	1.37	1185	1623.5	4.0	7.15	63.3	YES	290
16	1.3	1185	1540.5	4.0	7.16	63.1	YES	290
17	1.36	1185	1611.6	4.0	7.16	63.5	YES	290
18	1.37	1185	1623.5	4.0	7.14	63.1	YES	290
19	1.29	1185	1528.7	4.0	7.15	62.8	YES	290
20	1.28	1185	1516.8	5.0	7.17	59.0	YES	290
21	1.25	1185	1481.3	5.0	7.20	59.4	YES	290
22	1.2	1185	1422.0	4.0	7.21	63.5	YES	290
23	1.24	1185	1469.4	4.0	7.18	63.1	YES	290
24	1.26	1185	1493.1	4.0	7.17	63.0	YES	290
25	1.29	1185	1528.7	3.0	7.18	67.9	YES	290
26	1.31	1185	1552.4	4.0	7.14	62.7	YES	290
27	1.29	1185	1528.7	4.0	7.14	62.5	YES	290
28	1.27	1185	1505.0	4.0	7.17	63.1	YES	290

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350