

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: Lane  
 Month/Year: 23-Apr

System Name: Row River Valley Water District ID#: 41 01515 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03
12	0.03	0.03	0.03	0.03	0.03	0.03	0.03
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03
14	0.03	0.03	0.03	0.03	0.03	0.03	0.03
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU? <sup>2</sup> <u>Yes / No</u>	CT's met everyday? (see back) <u>Yes / No</u>	All Cl <sub>2</sub> residual at entry point $\geq$ 0.2 mg/l? <u>Yes / No</u>
All daily turbidity readings $\leq$ 5 NTU? <u>Yes / No</u>		

Notes: \_\_\_\_\_

James D Eckstine  
 SIGNATURE: James D Eckstine May-23  
 541-946-1655

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

PAGE 1 of 2



OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A  
 Disinfection *Giardia* Log Inactiv: 1.0

System Name: Row River Vally Water Dis ID#: 41 01515 Month/Year: 23-Apr

	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.42	1185	1682.7	7.0	7.28	54.5	YES	300
2	1.43	1185	1694.6	7.0	7.26	54.2	YES	300
3	1.41	1185	1670.9	7.0	7.24	53.7	YES	300
4	1.44	1185	1706.4	6.0	7.28	58.4	YES	300
5	1.46	1185	1730.1	6.0	7.25	57.9	YES	300
6	1.44	1185	1706.4	7.0	7.27	54.4	YES	300
7	1.4	1185	1659.0	7.0	7.30	54.8	YES	300
8	1.34	1185	1587.9	8.0	7.27	50.3	YES	300
9	1.35	1185	1599.8	7.0	7.28	54.1	YES	300
10	1.3	1185	1540.5	7.0	7.39	55.9	YES	300
11	1.28	1185	1516.8	7.0	7.43	56.6	YES	300
12	1.3	1185	1540.5	7.0	7.39	55.9	YES	300
13	1.33	1185	1576.1	7.0	7.33	54.9	YES	300
14	1.35	1185	1599.8	7.0	7.27	53.9	YES	290
15	1.34	1185	1587.9	8.0	7.23	49.6	YES	290
16	1.34	1185	1587.9	7.0	7.23	53.0	YES	290
17	1.32	1185	1564.2	7.0	7.24	53.1	YES	290
18	1.3	1185	1540.5	7.0	7.20	52.2	YES	290
19	1.32	1185	1564.2	7.0	7.21	52.5	YES	290
20	1.33	1185	1576.1	7.0	7.21	52.6	YES	290
21	1.31	1185	1552.4	7.0	7.27	53.6	YES	290
22	1.3	1185	1540.5	7.0	7.30	54.1	YES	290
23	1.28	1185	1516.8	7.0	7.28	53.6	YES	290
24	1.28	1185	1516.8	7.0	7.36	55.2	YES	290
25	1.36	1185	1611.6	7.0	7.33	55.1	YES	290
26	1.31	1185	1552.4	7.0	7.31	54.4	YES	290
27	1.33	1185	1576.1	8.0	7.32	51.2	YES	290
28	1.36	1185	1611.6	8.0	7.33	51.5	YES	290
29	1.4	1185	1659.0	8.0	7.37	52.5	YES	290
30	1.36	1185	1611.6	87.0	7.35	-0.5	YES	290
31								

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350