

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**


County: **Lane**  
 Month/Year: **23-Oct**  
 WTP : TP - **A**

System Name: **Row River Valley Water District ID#: 41 01515**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03
12	0.03	0.03	0.03	0.03	0.03	0.03	0.03
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03
14	0.03	0.03	0.03	0.03	0.03	0.03	0.03
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03
31	0.03	0.03	0.03	0.03	0.03	0.03	0.03

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup>	<b>Yes / No</b>	CT's met everyday? (see back)	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<b>Yes / No</b>	<b>Yes / No</b>	<b>Yes / No</b>

**Notes:**

James D Eckstine  
**SIGNATURE:**   
 541-946-1655

**Nov-23**

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.



OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A  
 Disinfection *Giardia* Log  
 Inactiv: 1.0

System Name: Row River Vally Water Dis ID#: 41 01515 Month/Year: 23-Oct

	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.08	1185	1279.8	13.0	7.19	33.7	YES	300
2	1.03	1185	1220.6	13.0	7.19	33.5	YES	300
3	1.05	1185	1244.3	13.0	7.21	33.8	YES	300
4	1.01	1185	1196.9	13.0	7.25	34.2	YES	300
5	1.08	1185	1279.8	14.0	7.22	31.9	YES	300
6	1.12	1185	1327.2	14.0	7.21	31.9	YES	300
7	1.25	1185	1481.3	13.0	7.24	35.0	YES	300
8	1.34	1185	1587.9	13.0	7.18	34.6	YES	300
9	1.37	1185	1623.5	14.0	7.20	32.7	YES	300
10	1.44	1185	1706.4	13.0	7.22	35.5	YES	300
11	1.14	1185	1350.9	12.0	7.24	37.4	YES	300
12	1.39	1185	1647.2	11.0	7.30	41.9	YES	300
13	1.43	1185	1694.6	11.0	7.25	41.4	YES	300
14	1.55	1185	1836.8	12.0	7.26	39.4	YES	290
15	1.31	1185	1552.4	13.0	7.20	34.7	YES	290
16	1.29	1185	1528.7	13.0	7.18	34.4	YES	290
17	1	1185	1185.0	14.0	7.22	31.6	YES	290
18	0.95	1185	1125.8	12.0	7.21	36.3	YES	290
19	1.06	1185	1256.1	12.0	7.23	36.9	YES	290
20	1.09	1185	1291.7	13.0	7.18	33.6	YES	290
21	0.8	1185	948.0	13.0	7.16	32.3	YES	290
22	0.78	1185	924.3	13.0	7.16	32.2	YES	290
23	0.86	1185	1019.1	14.0	7.18	30.6	YES	290
24	0.84	1185	995.4	12.0	7.19	35.6	YES	290
25	0.79	1185	936.2	12.0	7.21	35.6	YES	290
26	0.8	1185	948.0	9.0	7.25	44.0	YES	290
27	1.4	1185	1659.0	8.0	7.27	50.7	YES	290
28	1.45	1185	1718.3	8.0	7.23	50.2	YES	290
29	1.22	1185	1445.7	6.0	7.17	54.8	YES	290
30	1.14	1185	1350.9	6.0	7.15	53.9	YES	290
31	1.09	1185	1291.7	7.0	7.18	50.6	YES	290

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018