

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems


County: Lane
 Month/Year: 24-Jan

System Name: Row River Valley Water District ID#: 41 01515 WTP: TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03
3	0.04	0.03	0.03	0.03	0.03	0.03	0.03
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03
12	0.03	0.03	0.03	0.03	0.03	0.03	0.03
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03
14	0.04	0.04	0.04	0.04	0.04	0.04	0.04
15	0.04	0.03	0.03	0.03	0.03	0.03	0.04
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03
31	0.03	0.03	0.03	0.03	0.03	0.03	0.03

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ² <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point \geq 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings \leq 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:

James D Eckstine
 SIGNATURE: 
 541-946-1655

Feb-24

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Row River Vally Water Dis ID#: 41 01515 Month/Year: 24-Jan Disinfection *Giardia* Log Inactiv: 1.0

	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.03	1185	1220.6	7.0	7.18	50.3	YES	290
2	0.98	1185	1161.3	7.0	7.17	49.8	YES	290
3	1.06	1185	1256.1	7.0	7.16	50.1	YES	290
4	1.03	1185	1220.6	8.0	7.18	47.0	YES	290
5	0.95	1185	1125.8	8.0	7.23	47.4	YES	290
6	1.01	1185	1196.9	6.0	7.20	54.0	YES	290
7	1.08	1185	1279.8	6.0	7.24	55.3	YES	290
8	1.1	1185	1303.5	7.0	7.22	51.4	YES	290
9	1.03	1185	1220.6	7.0	7.41	54.6	YES	290
10	0.9	1185	1066.5	7.0	7.33	52.3	YES	290
11	1	1185	1185.0	7.0	7.31	52.5	YES	290
12	1.03	1185	1220.6	7.0	7.30	52.5	YES	290
13	0.93	1185	1102.1	7.0	7.39	53.6	YES	290
14	0.7	1185	829.5	8.0	7.43	49.5	YES	290
15	0.65	1185	770.3	8.0	7.35	47.8	YES	290
16	0.7	1185	829.5	7.0	7.32	50.9	YES	290
17	0.68	1185	805.8	7.0	7.37	51.7	YES	290
18	1.49	1185	1765.7	8.0	7.41	53.8	YES	290
19	1.13	1185	1339.1	8.0	7.37	50.9	YES	290
20	0.92	1185	1090.2	8.0	7.33	49.0	YES	290
21	0.82	1185	971.7	8.0	7.30	47.9	YES	290
22	0.76	1185	900.6	9.0	7.32	44.9	YES	290
23	0.87	1185	1031.0	9.0	7.31	45.3	YES	290
24	0.9	1185	1066.5	8.0	7.28	48.0	YES	290
25	0.87	1185	1031.0	9.0	7.32	45.4	YES	290
26	1	1185	1185.0	8.0	7.36	50.0	YES	290
27	0.98	1185	1161.3	9.0	7.40	47.3	YES	290
28	0.9	1185	1066.5	9.0	7.38	46.5	YES	290
29	0.9	1185	1066.5	9.0	7.32	45.6	YES	290
30	0.89	1185	1054.7	10.0	7.33	42.8	YES	290
31	0.93	1185	1102.1	10.0	7.29	42.4	YES	290

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018